



EUROPEAN COMMISSION

Brussels, 30 -10- 1998

SG(98) D/ 9136

97/4409

Sir,

I would like to draw your attention to the implementation by Ireland of Directive 80/778/EEC relating to the quality of water intended for human consumption ("the Directive").

**1. Background**

Complaints P97/4048 and P4409

In 1997, the Commission registered a complaint against Ireland under number P97/4409 concerning microbiological contamination of Irish drinking water supplies generally (one of the supplies being located at Ballycroy, County Mayo).

Referring to the reports of the Irish Environmental Protection Agency (EPA) on the quality of drinking water in Ireland, the complainants in P97/4409 drew attention to widespread problems of microbiological contamination (particularly of smaller supplies). The complainants were especially concerned at the public health implications.

The contamination of the Ballycroy drinking water supply was the subject of other more detailed complaints, namely P95/4078, which concerned the adverse environmental effects of sheep overgrazing in the west of Ireland, including adverse effects on the Ballycroy drinking water supply, and P97/4048. The Commission ultimately took action

---

On 4 May 1995, the Commission wrote to the Irish authorities requesting information (letter from [REDACTED], Director-General, Directorate-General XI, to [REDACTED], Irish Permanent Representative, XI/009587). On 4 June 1996, the Irish authorities responded (letter from [REDACTED], Environment Attaché to [REDACTED], Director-General).

Mr David ANDREWS, TD  
Minister for Foreign Affairs  
St. Stephen's Green 80

**IRL - DUBLIN 2**

Rue de la Loi 200, B-1049 Bruxelles/Wetstraat 200, B-1049 Brussel - Belgium - Office:  
Telephone: direct line (+32-2)29..... exchange 299.11.11 . Fax: 29.....  
Telex: COMEU B 21877 . Telegraphic address: COMEUR Brussels

under Article 169 of the Treaty in respect of P95/4078, focusing on sheep overgrazing problems affecting the implementation of Directive 79/409/EEC on the conservation of wild birds. Complaint P97/4048 again drew attention to the problems of the Ballycroy drinking water supply, claiming that the water supply (which serves about 170 houses and about 800 consumers) remained microbiologically contaminated; that, for some years prior to Ballycroy consumers discovering through private testing the microbiological contamination of their water supply in 1994, the competent authority, Mayo County Council (i.e. the sanitary authority charged with statutory responsibility for ensuring compliance with the Directive) knew from its own tests that the water was contaminated<sup>2</sup>; and that the Irish authorities did not take steps to discontinue the supply or take sufficient measures to ensure an uncontaminated supply and a notification of all consumers of the risks.

#### Correspondence with the Irish Authorities

Further to these complaints, the Commission wrote to the Irish authorities on 26 August 1997 seeking information and clarification on a range of issues.

By letter dated 23 April 1998, the Irish authorities provided a detailed response. In this response, the Irish authorities argued, on the basis of the decision of the European Court of Justice in Case C-42/89, *Commission v Belgium*, that the Directive did not apply to Irish group water schemes. Such schemes consist of water supplies provided for consumers by private trusts or companies where a public water supply is unavailable; the water supply for Ballycroy is an example. The Irish authorities also pointed to a range of measures intended to improve the quality of drinking water in Ireland and to protect drinking water sources, without however committing themselves to ensuring that all Irish drinking water supplies coming within the scope of the Directive comply with its requirements.

---

<sup>2</sup> The complainants provided the Commission with copies of two 1992 County Council test results which are marked "polluted supply, unfit for human consumption".

### Irish Drinking Water Reports

Since 1991, the Irish authorities have prepared and published annual reports on the quality of drinking water in Ireland<sup>3</sup>. Copies of these have been provided to the Commission, and cover the years 1989-1996 inclusive.

These reports point to serious and persistent problems of compliance with microbiological parameters 57 (total coliforms) and 58 (faecal coliforms) of Annex I of the Directive. These problems mainly affect group water schemes, but problems are also evident in a significant number of public water schemes. The number of contaminated group water schemes is very high, with the persistence of contamination over years of monitoring and the sometimes very high coliform values recorded adding to public health concerns. By way of illustration, the main report for the year 1996 notes, in relation to monitoring of group water schemes in County Mayo, "as is almost invariably the case with such schemes, there is a lengthy list of coliform exceedances, and it is indisputable that very many of the supplies are subject to serious faecal contamination. The salient cases are the faecal coliform occurrences in the Belmont (Kilconly) GWS, Crossboyne GWS, Furnace, Bucklagh GWS, Raith GWS and Tulrahan GWS, but it must

---

<sup>3</sup> The drinking water reports were initially prepared and published by the Environmental Research Unit attached to the Department of the Environment. Since 1993, responsibility for the reports has passed to the Irish Environmental Protection Agency (EPA). The report references are as follows:  
"The Quality of Drinking Water in Ireland, A Preliminary Report for the year 1989", Department of the Environment Environmental Research Unit, 1991, ISBN 1 85053 140 1;  
"The Quality of Drinking Water in Ireland, A Summary Report for the Year 1989", Department of the Environment Environmental Research Unit, 1991, ISBN 0 85053 139 0;  
"The Quality of Drinking Water in Ireland, A Report for the year 1990", Department of the Environment Environmental Research Unit, 1992 ISBN 1 85053 174 9;  
"The Quality of Drinking Water in Ireland, A Summary Report for the Year 1990", Department of the Environment Environmental Research Unit, 1992 ISBN 0 85053 175 7;  
"The Quality of Drinking Water in Ireland, A Report for the year 1991 with a Review of the Period 1989-1991", Environmental Protection Agency, 1993, ISBN 1 85053 193 5;  
"The Quality of Drinking Water in Ireland, A Summary Report for the year 1991 with an Overview of the Period 1989-1991", Environmental Protection Agency, 1993, ISBN 1 85053 196 X;  
"The Quality of Drinking Water in Ireland, A Report for the year 1992 with a Review of the Period 1990-1992", Environmental Protection Agency, 1994, ISBN 1 85053 198 6;  
"The Quality of Drinking Water in Ireland, A Report for the year 1993 with a Review of the Period 1991-1993", Environmental Protection Agency, 1995, ISBN 1 899965 01 7;  
"Ireland's Drinking Water, A Summary Report on its Quality in 1993", Environmental Protection Agency, 1995, ISBN 1 899965 02 7;  
"The Quality of Drinking Water in Ireland, A Report for the year 1994 with a Review of the Period 1992-1994", Environmental Protection Agency, 1996, ISBN 1 899965 27 0;  
"Ireland's Drinking Water, A Summary Report on its Quality in 1994", Environmental Protection Agency, 1996, ISBN 1 899965 28 9;  
"The Quality of Drinking Water in Ireland, A Report for the year 1995 with a Review of the Period 1993-1995", Environmental Protection Agency, 1996, ISBN 1 899965 44 0;  
"Ireland's Drinking Water, A Summary Report on its Quality in the Period 1993-1995", Environmental Protection Agency, 1996, ISBN 1 899965 45 9;  
"The Quality of Drinking Water in Ireland, A Report for the year 1996 with a Review of the Period 1994-1996", Environmental Protection Agency, 1997, ISBN 1 899965 80 7;  
"Ireland's Drinking Water, A Summary Report on its Quality in 1996 with an Overview of the Period 1994-1996", Environmental Protection Agency, 1996, ISBN 1 899965 45 9.

be stressed that every case of faecal contamination - however low - is a matter of serious public health concern"<sup>4</sup>.

## 2. Legal Arguments

### Directive and Irish Implementing Legislation

Article 2 of the Directive defines "water intended for human consumption" to mean *inter alia* all water used for that purpose, either in its original state or after treatment, regardless of origin, supplied for consumption.

Article 7(1) of the Directive requires Member States to fix values applicable to water intended for human consumption for the parameters shown in Annex I. Article 7(3) limits the discretion of Member States in fixing these values. Article 7(6) obliges Member States to take the necessary measures to ensure that water intended for human consumption at least meets the requirements specified in Annex I.

Article 9 of the Directive makes provision for derogations, but provides that in no case shall derogations relate to toxic or microbiological factors.

Article 12 of the Directive provides that Member States shall take all necessary steps to ensure regular monitoring of water intended for human consumption, and also provides that Member States shall conform with Annex II.

Article 18 of the Directive provides that Member States shall bring into force the laws, regulations and administrative provisions necessary to comply with the Directive and its annexes within two years following notification. The Directive was notified to Ireland on 18 July 1980. Hence the deadline under Article 18 expired on 18 July 1982

Article 19 of the Directive provides that Member States shall take the necessary measures to ensure that the quality of water intended for human consumption complies with the Directive within five years of its notification. The compliance deadline under Article 19 therefore expired on 18 July 1985.

By letter dated 6 May 1988, Ireland communicated as its implementing legislation for the Directive S.I. No 81 of 1988, European Communities (Quality of Water Intended for Human Consumption) Regulations, 1988.

By letter dated 19 November 1992, Ireland informed the Commission that Section 58 of the Environmental Protection Agency Act, 1992 gave the Irish Environmental Protection Agency a supervisory role in relation to the monitoring of drinking water.

---

<sup>4</sup> P213 of the Report.

*Non-compliance with Micro-biological Parameters 57 and 58 in Public Water Schemes*

Ireland does not dispute the applicability of the Directive to Irish public water schemes.

Inasmuch as the abovementioned official drinking water reports disclose non-compliance with parameters 57 and 58 of Annex I of the Directive in certain public water schemes, Ireland is in breach of its duties under Articles 7(6) and 19 of the Directive. Details of non-compliant schemes are set out in the said drinking water reports. By way of extrapolation, names and details of micro-biologically non-compliant schemes for the years 1993-1995 inclusive are set out in the table annexed to the present letter.

*Non-compliance with Microbiological Parameters 57 and 58 in Group Water Schemes*

As mentioned above, the Irish authorities in their letter dated 23 April 1998 argued that the Directive was inapplicable to Irish group water schemes.

The Commission does not accept this argument for several reasons.

First, as regards the scope of application of the Directive, the decision of the European Court of Justice in Case C-42/89, *Commission v Belgium*, hinges on the notion of "supply" to consumers. The Court drew a distinction between water "supplied for human consumption" and water extracted from private wells for domestic use, accepting that the latter were not covered by the Directive because the notion of a supply to consumers did not arise. However, the notion of supply to consumers is clearly present in the role that group water schemes play in providing water. In essence, such schemes are suppliers of water to private and commercial consumers in the same way that water companies elsewhere in the Community provide water supplies to their consumers.

Secondly, there is a formal distinction between group water schemes and private individuals acting on their own behalf. In terms of their legal constitution, the schemes are either trusts or corporate entities, with all the fixed and current assets of a scheme owned and controlled by the trust or company, and not by the individual consumers. The example of Ballycroy illustrates this. The water network, which as previously mentioned services in the region of 800 consumers, is operated by Ballycroy Water Company Limited, a limited company established under Irish law.

Thirdly, the Irish authorities themselves have recognised a distinction between group water schemes and water which individuals provide for themselves. The abovementioned drinking water reports describe group water schemes in a category apart from other small private supplies or wells. The Irish Department of the Environment has also described group water schemes in terms of a separate category: its May 1997 Environment bulletin, points out that an estimated 55 000 houses are connected to privately sourced group schemes, 90 000 houses to publicly sourced group schemes and that the 1991 Census showed that there were an estimated 130 000 households with their own private water supplies. The Commission considers that it is only the last category (i.e. the estimated 130 000 households) that falls outside the scope of the Directive on the basis of the interpretation in Case C-42/89.

Fourthly, the arrangements between group water schemes and consumers are comparable with the arrangements between any other type of utility and consumers. A group water scheme will only provide a water supply to a consumer on payment of a capital charge for installation, and will only supply water on payment of a regular standing charge. The relationship between consumer and scheme is contractual, normally confirmed by a formal written contract.

Fifthly, in many cases group schemes will draw on sources of water which are in public ownership or under public control, as is evident in the abovementioned Environment Bulletin.

Sixthly, group water schemes can in practice act as commercial drinking water providers to public bodies. This is again illustrated by the case of Ballycroy. The Ballycroy Water Company Limited sells water to Mayo County Council to supply the population of Inishbiggle Island. The Council buys the water on a metered basis and takes it from the Ballycroy network directly to Inishbiggle. In addition, the Council has paid capital charges to the Water Company in respect of water supply to Council houses in Ballycroy. The Irish Department of Education and Department of Health also benefit from the water supply, inasmuch as three national schools and a medical centre are supplied.

For all the above reasons, the Commission does not accept that group water schemes fall outside the scope of application of the Directive.

Given this, and given that the abovementioned official drinking water reports as well as correspondence in connection with Ballycroy disclose non-compliance with parameters 57 and 58 of Annex I of the Directive in many group water schemes, the Commission considers that Ireland is in breach of its duties under Articles 7(6) and 19 of the Directive. Details of non-compliant schemes are set out in the said drinking water reports as well as correspondence in connection with Ballycroy. By way of extrapolation, names and details of micro-biologically non-compliant schemes for the years 1993-1995 inclusive are set out in the Table annexed to the present letter.

#### Conformity of the Irish Implementing Legislation

An examination of the Irish implementing legislation for the Directive, S.I. No 81 of 1988, European Communities (Quality of Water Intended for Human Consumption) Regulations, 1988, indicates that the legislation is not in conformity with the Directive in respect of group water schemes.

Irish sanitary authorities are the competent authorities assigned with the task of complying with these Regulations (and thereby ensuring compliance with the Directive). Article 4 of the Regulations states that "it shall be the duty of a sanitary authority to take the necessary measures to ensure that water intended for human consumption meets the requirements of these Regulations." However, in a situation where monitoring discloses a compliance problem with a group water scheme, Article 8 of the Regulations limits the duty of a sanitary authority to giving a user warning and advising those operating the scheme of the measures which should be taken for the improvement of the water quality. No duty is imposed on the companies or trusts operating group water schemes to comply with drinking water standards, and sanitary authorities are not given any powers under the Regulations to require group water schemes to comply with such standards.

The way in which the Irish legislation works is illustrated by the example of Ballycroy. In their letter to the Commission of 4 June 1996<sup>5</sup>, the Irish authorities affirmed, with reference to the contamination of the group water scheme, that "it is a matter for the group scheme members and management to provide the necessary treatment facilities to maintain water quality at acceptable levels." It is implicit in this statement that, as far as the Irish authorities are concerned, a sanitary authority - the only authority with statutory duties under the Regulations in respect of water supplied for consumption - is not responsible for maintaining satisfactory water quality in respect of a group water scheme. As the group water scheme is under no statutory obligation under the Regulations to maintain such water quality in accordance with the Directive, the Regulations effectively treat the requirements of Annex I of the Directive as being at most in the nature of advisory guidelines so far as a group water scheme is concerned.

This falls short of what is required under the Directive, which leaves no ambiguity as regards the binding character of Annex I.

Thus even were Ireland to accept that group water schemes come within the scope of application of the Directive, its transposition of the Directive would be deficient in relation to such schemes. As a result, the Commission considers that Ireland has failed to comply with its duties under Articles 7(6), 18 and 19 of the Directive.

### **3. Conclusions**

In conclusion, the Commission considers that Ireland is in breach of its obligations under Articles 7(6) and 19 of the Directive in as much as it has failed to ensure compliance with microbiological parameters 57 (total coliforms) and 58 (faecal coliforms) of Annex I of the Directive in respect of certain public water schemes and certain group water schemes (identified in official drinking water reports and in correspondence concerning Ballycroy), and is further in breach of its obligations under Articles 7(6), 18 and 19 of the Directive inasmuch as it has failed, in its implementing legislation, to reflect the binding character of the requirements of Annex I of the Directive in relation to group water schemes.

In these circumstances, acting under Article 169 of the EC Treaty, the Commission asks the Irish Government to submit its observations on the matters set out in this letter within two months of receiving it.

---

<sup>5</sup> See footnote 1.

After taking note of these observations, the Commission may, if necessary, deliver a Reasoned Opinion under Article 169. It may also deliver a Reasoned Opinion if those observations fail to reach it within the time stated.

Yours faithfully,  
For the Commission

A thick, black horizontal scribble used to redact the signature of Ritt Bjerregaard.

Ritt BJERREGAARD  
Member of the Commission

Encl.

## TABLE

**Bacteriologically Contaminated****DRINKING WATER SUPPLIES IN IRELAND  
1993 to 1995 inclusive****Arklow Contaminated Drinking Water Supplies:**

1993 (Local Authority Supply): Arklow UDC - coliforms 0/100mls  
 1994 (Local Authority Supply): Arklow UDC - coliforms 0/100mls  
 1995 (Local Authority Supply): Arklow UDC - coliforms 1/100mls

**Bray Contaminated Drinking Water Supplies:**

1993 (Local Authority Supply): Bray UDC - coliforms 1/100mls  
 1994 (Local Authority Supply): Bray UDC - coliforms 1/100mls  
 1995 (Local Authority Supply): Bray UDC - coliforms 8/100mls

**County Carlow Contaminated Drinking Water Supplies:****1993 (Local Authority Supply): (5 supplies)**

Borris - coliforms 5/100mls, Hacketstown - coliforms 3/100mls, Leighlinbridge - faecal coliforms 2/100mls, Carlow N.Regional - coliforms 2/100mls, Tinnahinch - coliforms - 4/100mls.

**1993 (Group Water Schemes): (6 supplies)**

Ballinabranagh - coliforms 2/100mls, Ballyellen - faecal coliforms 2/100mls, Ballyloo - coliforms 160/100mls, Killerrig-Straboe - coliforms 1/100mls, Nurney - coliforms 4/100mls, Tankardstown - faecal coliforms 6/100mls.

**1994 (Local Authority Supply): (5 supplies)**

Borris - coliforms 6/100mls, Carlow C. Regional - coliforms 1/100mls, Hacketstown - coliforms 4/100mls, Carlow N.Regional - coliforms 2/100mls, Tullow - coliforms - 2/100mls.

**1994 (Group Water Schemes): (3 supplies)**

Ballyellen - faecal coliforms 3/100mls, Graiguenaspidogue - coliforms 1/100mls; Newtown - coliforms 15/100mls

**1995 (Local Authority Supply): (4 supplies)**

Carrigduff - coliforms 1/100mls, Carlow N. Regional - coliforms 1/100mls, Tinnahinch - coliforms 1/100mls, Tullow - faecal coliforms - 5/100mls.

**1995 (Group Water Schemes): (4 supplies)**

Ballinabranagh - coliforms 6/100mls, Ballyellen - coliforms 18/100mls, Ballyloughan - coliforms 2/100mls, Glynn-St Mullins - faecal coliforms 82/100mls

**Carrickmacross Contaminated Drinking Water Supplies:**

1993 (Local Authority Supply): Carrickmacross UDC - coliforms 5/100mls  
 1994 (Local Authority Supply): Carrickmacross UDC - coliforms 1/100mls  
 1995 (Local Authority Supply): Carrickmacross UDC - coliforms 1/100mls

**Castleblayney Contaminated Drinking Water Supplies:**

1993 (Local Authority Supply): Castleblayney UDC - coliforms 1/100mls

1994 (Local Authority Supply): Castleblayney UDC - coliforms 15/100mls

1995 (Local Authority Supply): Castleblayney UDC - faecal coliforms 3/100mls

**County Cavan Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (14 supplies)**

Arva - faecal coliforms 6/100mls, Bailieborough - faecal coliforms 2/100mls, Ballinagh - faecal coliforms 3/100mls, Ballyjamesduff - faecal coliforms 48/100mls, Blacklion - coliforms 1/100mls, Dowra - coliforms 8/100mls, Killeshandra - faecal coliforms 4/100mls, Kilnaleck - coliforms 18/100mls, Kingscourt - faecal coliforms 28/100mls, Lough Gowna - coliforms 8/100mls, Mullagh - coliforms 1300/100mls, Shercock - coliforms 85/100mls, Swanlinbar - faecal coliforms 6/100mls, Virginia - faecal coliforms 10/100mls.

**1993 (Group Water Schemes): (23 supplies)**

Aughawillin - coliforms 16/100mls, Ballymagovern - coliforms 22/100mls, Barnagrove - faecal coliforms 2/100mls, Billis/Lavey - faecal coliforms 112/100mls, Bunnoe - faecal coliforms 3/100mls, Butlersbridge - faecal coliforms 2/100mls, Clifferna - coliforms 1/100mls, Corlough - faecal coliforms 81/100mls, Derrycassan - faecal coliforms 2/100mls, Derrynakesk - faecal coliforms 6/100mls, Drumcrow - faecal coliforms 15/100mls, Drummullen - faecal coliforms 3/100mls, Gartylough - faecal coliforms 3/100mls, Glangevlin - faecal coliforms 48/100mls, Killawaun - coliforms 19/100mls, Killinkere - faecal coliforms 2/100mls, Killygreagh - coliforms 39/100mls, Kinaghmore - coliforms 9/100mls, Redhills - faecal coliforms 38/100mls, Sralaghan - faecal coliforms 33/100mls, Tullyunchin - faecal coliforms 60/100mls, Tunnyduff - faecal coliforms 1/100mls, Turfad - faecal coliforms 1/100mls.

**1994 (Local Authority Supplies): (6 supplies)**

Arva - faecal coliforms 10/100mls, Bailieborough - coliforms 8/100mls, Ballyconnell - coliforms 7/100mls, Ballyjamesduff - coliforms 2/100mls, Kilnaleck - coliforms 16/100mls, Virginia - coliforms 6/100mls.

**1994 (Group Water Schemes): (36 supplies)**

Ballyhaise - faecal coliforms 560/100mls, Ballymagovern - faecal coliforms 1/100mls, Barnagrove - faecal coliforms 32/100mls, Billis - faecal coliforms 5/100mls, Billis/Lavey - faecal coliforms 10/100mls, Bunnoe - faecal coliforms 13/100mls, Butlersbridge - faecal coliforms 2/100mls, Clifferna - coliforms 18/100mls, Corlough - faecal coliforms 96/100mls, Coronea - coliforms 4/100mls, Corville - coliforms 3/100mls, Currin/Ballyconnell - faecal coliforms 20/100mls, Derrynakesh - faecal coliforms 105/100mls, Derryvahan - faecal coliforms 33/100mls, Dhuish - faecal coliforms 4/100mls, Doobally - faecal coliforms 2/100mls, Drumillig - coliforms 3/100mls, Drumkeeran Road/Dowra - faecal coliforms 6/100mls, Dunaree - coliforms 6/100mls, Gartylough - faecal coliforms 30/100mls, Glangevlin - faecal coliforms 22/100mls, Glasleck - faecal coliforms 6/100mls, Gortnacleigh/Milltown - faecal coliforms 4/100mls, Gowlan/Blacklion - faecal coliforms 31/100mls, Gowlan/Corlough - faecal coliforms 91/100mls, Gubaveeny - faecal coliforms 10/100mls, Kildallan - faecal coliforms 6/100mls, Kill - coliforms 6/100mls, Kiltyglassan - faecal coliforms 28/100mls, Kinaghmore - coliforms 3/100mls, Knockbride - faecal coliforms 3/100mls, Milltown - faecal coliforms 43/100mls, Redhills - faecal coliforms 2/100mls, Templeport - faecal coliforms 4/100mls, Tullyunchin - faecal coliforms 13/100mls, Turfad - faecal coliforms 1/100mls.

**1995 (Local Authority Supplies): (12 supplies)**

Bailieborough - faecal coliforms 1/100mls, Ballyjamesduff - coliforms 2/100mls, Bawnboy - faecal coliforms 14/100mls, Butlersbridge - coliforms 31/100mls, Cavan Regional - coliforms >100/100mls, Cootehill - coliforms 2/100mls, Kilnaleck - coliforms 8/100mls, Kingscourt - coliforms 2/100mls, Mullagh - faecal coliforms 4/100mls, Sherlock - coliforms 16/100mls, Swanlinbar - faecal coliforms 6/100mls, Virginia - faecal coliforms 10/100mls.

**1995 (Group Water Schemes): (6 supplies - 24 supply results missing)**

Billis/Lavey - faecal coliforms 9/100mls, Brusky/Killydoon - faecal coliforms 76/100mls, Crossdoney - faecal coliforms 9/100mls, Galboly/The Vale - faecal coliforms 16/100mls, Lavagh/Ballyheelan - faecal coliforms 5/100mls, Tullyunchin - faecal coliforms 26/100mls

**County Clare Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)**

Tulla - faecal coliforms 1/100mls

**1993 (Group Water Schemes): (1 supply)**

Tubber - faecal coliforms 1/100mls, 2 private wells also contaminated.

**1994 (Local Authority Supplies): (10 supplies)**

Ballyvaughan-Turlough - faecal coliforms 90/100mls, Broadford - faecal coliforms 72/100mls, Corofin Regional - coliforms 10/100mls, Crusheen - faecal coliforms 38/100mls, Doolough (New) - coliforms 5/100mls, Feakle - coliforms 14/100mls, Flagmount - faecal coliforms 1/100mls, Kildysart - faecal coliforms 50/100mls, Knockalishen - coliforms 6/100mls, Whitegate - coliforms 5/100mls

**1995 (Local Authority Supplies): (8 supplies)**

Ballyvaughan - faecal coliforms >100/100mls, Ballyvaughan-Newtown - faecal coliforms 55/100mls, Broadford - faecal coliforms 90/100mls, Carron - faecal coliforms 4/100mls, Killaloe - faecal coliforms 2/100mls, Newmarket-on-Fergus - coliforms 14/100mls, Scarrif - faecal coliforms 4/100mls, Turlough - faecal coliforms 10/100mls,

**Clones Contaminated Drinking Water Supplies:**

**1994 (Local Authority Supply): Clones UDC - faecal coliforms 92/100mls**

**1995 (Local Authority Supply): Clones UDC - faecal coliforms 5/100mls**

**Clonmel Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supply): Clonmel UDC Glenary - faecal coliforms 700/100mls**

**1994 (Local Authority Supply): Clonmel UDC Glenary - faecal coliforms 88/100mls, Clonmel UDC Poulavanogue - faecal coliforms 3/100mls**

**1995 (Local Authority Supply): Clonmel UDC Glenary - faecal coliforms 26/100mls**

**Cork Corporation Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies):**

Cork City - coliforms 100/100 mls

**1994 (Local Authority Supplies):**

Cork City - coliforms From 1/100mls to 100/100 mls

**1995 (Local Authority Supplies):**

Cork City - coliforms 7/100mls

**County Cork Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (52 supplies)**

SOUTHERN AREA: Aghabullogue - coliforms 1/100mls, Ballinadee - coliforms 2/100mls, Ballinagree - faecal coliforms 1/100mls, Ballingeary - faecal coliforms 32/100mls, Ballinspittle New - faecal coliforms 1/100mls, Ballinspittle Old - faecal coliforms 88/100mls, Ballymakeera - faecal coliforms 4/100mls, Belgooly - coliforms 37/100mls, Clondrohid - faecal coliforms 3/100mls, Coachford - faecal coliforms 5/100mls, Cobh Regional - coliforms 4/100mls, Coole East - coliforms 4/100mls, Dungourney - faecal coliforms 1/100mls, Enniskeane - faecal coliforms 6/100mls, Glashaboy-Little Island - coliforms 1/100mls, Grenagh - coliforms 1/100mls, Inniscarra-Ballincollig - coliforms 4/100mls, Inniscarra-Curraleigh - faecal coliforms 1/100mls, Killeagh - coliforms 7/100mls, Kilnamartyra - faecal coliforms 3/100mls, Kinsale - faecal coliforms 3/100mls, Macroom Urban - faecal coliforms 12/100mls, Minane Bridge - coliforms 3/100mls, Mogeely-Castlemartyr - coliforms 6/100mls, Stoneview/Blarney - coliforms 3/100mls, Whitegate - coliforms 6/100mls.

NORTHERN AREA: Bweeng - faecal coliforms 1/100mls, Conna Village - coliforms 1/100mls, Doneraile - faecal coliforms 1/100mls, Dromahane - faecal coliforms 1/100mls, Kiskeam - faecal coliforms 1/100mls, Lyre - coliforms 1/100mls, Mitchelstown-Galtee - faecal coliforms 2/100mls.

WESTERN AREA: Ardgroom - faecal coliforms 1/100mls, Ballineen - coliforms 1/100mls, Baltimore - coliforms 1/100mls, Baltimore-Castletownshend - coliforms 1/100mls, Bantry New - faecal coliforms 2/100mls, Bantry Old - faecal coliforms 2/100mls, Cahermore - faecal coliforms 34/100mls, Cape Clear - faecal coliforms 1/100mls, Castletownbere New - faecal coliforms 9/100mls, Castletownbere Old - faecal coliforms 8/100mls, Drimnagh - coliforms 2/100mls, Durrus - coliforms 3/100mls, Glengarriff - coliforms 2/100mls, Goleen - coliforms 1/100mls, Kealkill - faecal coliforms 12/100mls, Schull-Ballydehob - coliforms 1/100mls, Timoleague - coliforms 2/100mls, Timoleague/Courtmacsherry - coliforms 1/100mls, Toormore - coliforms 1/100mls.

**1994 (Local Authority Supplies): (59 supplies)**

SOUTHERN AREA: Aghabullogue - coliforms 1/100mls, Ballinadee - faecal coliforms 5/100mls, Ballinspittle New - faecal coliforms 56/100mls, Ballinspittle Old - faecal coliforms 1/100mls, Belgooly - faecal coliforms 1/100mls, Coachford - faecal coliforms 2/100mls, Coole East - coliforms 29/100mls, Enniskeane - coliforms 1/100mls, Glenville - coliforms 1/100mls, Inch/Youghal - faecal coliforms 2/100mls, Inchigeela - faecal coliforms 12/100mls, Inniscarra-Ballincollig - coliforms 2/100mls, Inniscarra-Curraleigh - coliforms 2/100mls, Inniscarra-Ringaskiddy - coliforms 43/100mls, Kilbrittain - faecal coliforms 17/100mls, Kilmore - coliforms 17/100mls, Kilnamartyra - coliforms 2/100mls, Kinsale - coliforms 2/100mls, Newcestown - faecal coliforms 25/100mls, Whitegate - faecal coliforms 1/100mls.

NORTHERN AREA: Allow Regional - faecal coliforms 17/100mls, Ballydesmond - faecal coliforms 120/100mls, Banteer - faecal coliforms 23/100mls, Bweeng - coliforms 1/100mls, Caherbarnagh - faecal coliforms 1/100mls, Catletownroche - faecal coliforms 2/100mls, Cregane - faecal coliforms 8/100mls, Doneraile - coliforms 3/100mls, Downing Bridge - faecal coliforms 10/100mls, Dromahane - faecal coliforms 7/100mls, Fermoy - coliforms 1/100mls, Kilally/Kilworth - faecal coliforms 19/100mls, Kildorrery - coliforms 1/100mls, Kiskeam - faecal coliforms 16/100mls, Laharn - faecal coliforms 3/100mls, Lyre - coliforms 2/100mls, Mallow - coliforms 1/100mls, Nad - coliforms 1/100mls, Rockchapel - coliforms 9/100mls, Watergrasshill - faecal coliforms 6/100mls.

WESTERN AREA: Adrigole - faecal coliforms 88/100mls, Allihies - faecal coliforms 7/100mls, Ballineen - coliforms 42/100mls, Bantry Old - coliforms 1/100mls, Cahermore - coliforms 2/100mls, Cape Clear Island - coliforms 3/100mls, Castletownbere New - coliforms 1/100mls, Castletownbere Old - faecal coliforms 2/100mls, Durrus - coliforms 8/100mls, Kealkill - faecal coliforms 18/100mls, Leap - faecal coliforms 2/100mls, Leap-Glandore - faecal coliforms 2/100mls, Leap-Union Hall - faecal coliforms 1/100mls, Schull - coliforms 3/100mls, Snave - faecal coliforms 58/100mls, Timoleague - coliforms 2/100mls, Toormore - coliforms 2/100mls, Whiddy Island - faecal coliforms 15/100mls

**1995 (Local Authority Supplies): (68 supplies)**

SOUTHERN AREA: Aghabullogue - coliforms 5/100mls, Ballinadee - faecal coliforms 7/100mls, Ballinagree - coliforms 4/100mls, Ballinacurrig-Lisgoold - faecal coliforms 7/100mls, Ballingearry - coliforms 6/100mls, Ballinspittle Old - faecal coliforms 1/100mls, Ballymacoda - faecal coliforms 1/100mls, Ballymakeera - coliforms 3/100mls, Ballyphilip - coliforms 1/100mls, Bandon Regional - coliforms 4/100mls, Brownes Mills-Summercove - faecal coliforms 9/100mls, Carrickadrohid - faecal coliforms 1/100mls, Clondrohid - faecal coliforms 5/100mls, Coachford - faecal coliforms 1/100mls, Cobh Regional - coliforms 5/100mls, Donoughmore - coliforms 1/100mls, Dungourney - faecal coliforms 1/100mls, Glanmire Regional - faecal coliforms 20/100mls, Glenville - coliforms 1/100mls, Grenagh - coliforms 6/100mls, Inchigeelagh - coliforms 31/100mls, Inniscarra-Ballincollig - coliforms 31/100mls, Inniscarra-Curraleigh - coliforms 1/100mls, Inniscarra-Little Island - coliforms 2/100mls, Inniscarra-Moneygourney - coliforms 2/100mls, Inniscarra-Ringaskiddy - coliforms 2/100mls, Innishannon - coliforms 1/100mls, Kinsale - coliforms 4/100mls, Middleton Urban - faecal coliforms 12/100mls, Whites Cross - faecal coliforms 4/100mls.

NORTHERN AREA: Allow Regional - faecal coliforms 3/100mls, Banteer - faecal coliforms 9/100mls, Boherbue - faecal coliforms 1/100mls, Buttervant - faecal coliforms 2/100mls, Castletownroche - faecal coliforms 19/100mls, Dromahane - faecal coliforms 20/100mls, Fermoy - faecal coliforms 2/100mls, Glanworth - faecal coliforms 22/100mls, Kilally/Kilworth - coliforms 13/100mls, Kildorrery - faecal coliforms 6/100mls, Killavullen - coliforms 2/100mls, Kiskeam - faecal coliforms 52/100mls, Knocknagree - coliforms 9/100mls, Mouth North - coliforms 35/100mls, Nad - faecal coliforms 7/100mls, Newmarket-Kanturk No 1 - faecal coliforms 26/100mls, Newmarket-Kanturk No 2 - faecal coliforms 12/100mls, Rockchapel - faecal coliforms 2/100mls, Tullylease - coliforms 2/100mls, Watergrasshill - faecal coliforms 24/100mls.

WESTERN AREA: Ardgroom - faecal coliforms 1/100mls, Baltimore-Tragumna - coliforms 2/100mls, Bantry Old - faecal coliforms 87/100mls, Cape Clear Island - faecal coliforms 4/100mls, Castletownbere New - faecal coliforms 2/100mls, Castletownbere Old - faecal coliforms 4/100mls, Clonakilty Town - coliforms 1/100mls, Crookhaven - faecal coliforms 1/100mls, Drimoleague - faecal coliforms 9/100mls, Kealkill - faecal coliforms 14/100mls, Leap - coliforms 1/100mls, Leap-Union Hall - coliforms 1/100mls, Schull - coliforms 1/100mls, Skibereen - faecal coliforms 1/100mls, Snave - faecal coliforms 60/100mls, Timoleague - coliforms 2/100mls, Timoleague-Courtmacsherry - coliforms 1/100mls, Whiddy Island - coliforms 1/100mls

**County Donegal Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (32 supplies)**

Ardagh/St Johnston - faecal coliforms 6/100ml, Ballintra - faecal coliforms 6/100ml, Ballyshannon - faecal coliforms 26/100ml, Buncrana - coliforms 6/100ml, Bundoran - faecal coliforms 4/100ml, Carrick/Teelin - faecal coliforms 136/100ml, Carrick Old - faecal coliforms 20/100ml, Carrigart/Downings - faecal coliforms 30/100ml, Cashel/Gleneely - faecal coliforms 2/100ml, Creeslough/Dunfanaghy - faecal coliforms

200/100ml, Donegal (River Eske) - faecal coliforms 2/100ml, Fanad West/Tullyconnell - faecal coliforms 5/100ml, Fintown - faecal coliforms 140/100ml, Glenties/Ardara - faecal coliforms 4/100ml, Gortahork/Falcarragh - faecal coliforms >100/100ml, Greencastle - coliforms 6/100ml, Inishowen East - coliforms 2/100ml, Inishowen West - faecal coliforms 4/100ml, Killea - faecal coliforms 140/100ml, Killybegs - faecal coliforms 48/100ml, Letterkenny - faecal coliforms 8/100ml, Lettermacaward - faecal coliforms 16/100ml, Lough Mourne - faecal coliforms 14/100ml, Malin Head - faecal coliforms 66/100ml, Malinmore - faecal coliforms 1/100ml, Manorcunningham - coliforms 4/100ml, Meenreagh - coliforms 6/100ml, Milford - coliforms 4/100ml, Mountcharles - faecal coliforms 5/100ml, Pettigo - coliforms 8/100ml, Rosbeg - faecal coliforms 20/100ml, Rosses Regional - faecal coliforms 4/100ml.

**1993 (Group Water Schemes): (7 supplies)**

Churchill - faecal coliforms 2/100ml, Desertegney - faecal coliforms 22/100ml, Fintragh - faecal coliforms 3200/100ml, Marameelan - coliforms 4/100ml, Meenamore - coliforms 2/100ml, Teelin - faecal coliforms 1/100ml, Tober/Castlethird - faecal coliforms 2/100ml

**1994 (Local Authority Supplies): (26 supplies)**

Arranmore Island - coliforms 23/100ml, Ballintra - faecal coliforms 1/100ml, Ballyshannon - faecal coliforms 1/100ml, Carrick/Teelin - faecal coliforms 13/100ml, Cashel/Gleneely - faecal coliforms 400/100ml, Cranford - coliforms 2/100ml, Creeslough/Dunfanaghy - faecal coliforms 39/100ml, Donegal (Cullionboy) - coliforms 2/100ml, Donegal (Mountcharles Lower) - faecal coliforms 26/100ml, Donegal (River Eske) - coliforms 32/100ml, Fintown - faecal coliforms 6/100ml, Gortahork/Falcarragh - faecal coliforms 20/100ml, Inishowen East - faecal coliforms 1/100ml, Killea - faecal coliforms 1/100ml, Letterkenny - faecal coliforms 1/100ml, Lettermacaward - faecal coliforms 3/100ml, Lifford - coliforms 2/100ml, Lough Mourne - coliforms 4/100ml, Malin Head - coliforms 4/100ml, Manorcunningham - faecal coliforms 214/100ml, Mountcharles Upper - faecal coliforms 1/100ml, Moville - coliforms 10/100ml, Pettigo - coliforms 200/100ml, Portnoo-Narin - faecal coliforms 5/100ml, Rosbeg - faecal coliforms 4/100ml, Rosses Regional - coliforms 2/100ml.

**1994 (Group Water Schemes): (14 supplies)**

Ballymagroaty - faecal coliforms 4/100ml, Bunn - faecal coliforms 4/100ml, Cappagh-Teelin - faecal coliforms 17/100ml, Carrowmeena - faecal coliforms 70/100ml, Churchill - faecal coliforms 18/100ml, Desertegney - faecal coliforms 26/100ml, Drumcairn - faecal coliforms 35/100ml, Drumogill - faecal coliforms 4/100ml, Fintragh - faecal coliforms 39/100ml, Largymore - faecal coliforms 3/100ml, Owenteskna - faecal coliforms 9/100ml, Tovercastlethird - faecal coliforms 1/100ml, Townawilly - faecal coliforms 26/100ml, Tullintain - faecal coliforms 2/100ml.

**1995 (Local Authority Supplies): (22 supplies)**

Ardagh-St Johnston - faecal coliforms 1/100ml, Arranmore Island - coliforms 190/100ml, Ballintra - faecal coliforms 1/100ml, Ballyshannon - coliforms 4/100ml, Bundoran Urban - faecal coliforms 1/100ml, Burnfoot - faecal coliforms 1/100ml, Carrick/Teelin - faecal coliforms 1/100ml, Carrigart-Downings - coliforms 2/100ml, Cashel/Glencolumbcille - faecal coliforms 1/100ml, Cashel/Gleneely - faecal coliforms 5/100ml, Cranford-Carrigart - faecal coliforms 1/100ml, Creeslough/Dunfanaghy - faecal coliforms 1/100ml, Donegal (River Eske) - faecal coliforms 20/100ml, Dunkineely - faecal coliforms 1/100ml, Fanad-West - coliforms 2/100ml, Frosses-Inver - coliforms 2/100ml, Glenties-Ardara - faecal coliforms 3/100ml, Gortahork/Falcarragh - faecal coliforms 1/100ml, Killea - coliforms 4/100ml, Killybegs - faecal coliforms 1/100ml, Letterkenny - faecal coliforms 3/100ml, Lifford - faecal coliforms 45/100ml, Lough Mourne - faecal coliforms 2/100ml, Malinmore - coliforms 3/100ml, Manorcunningham - faecal coliforms 12/100ml, Meenreagh - faecal coliforms 2/100ml, Mountcharles Upper - faecal

coliforms 3/100ml, Pettigo - faecal coliforms 4/100ml, Portnoo-Narin - coliforms 1/100ml, Rosbeg - coliforms 1/100ml, Rosses Regional - coliforms 8/100ml.

**1995 (Group Water Schemes): (20 supplies)**

Ballymagroaty - faecal coliforms 6/100ml, Bavin - coliforms 2/100ml, Bunn - faecal coliforms 2/100ml, Cappagh-Teelin - faecal coliforms 5/100ml, Carrowmeena - faecal coliforms 5/100ml, Cashelard - faecal coliforms 1/100ml, Churchill - faecal coliforms 81/100ml, Cloghan-Glencolumbcille - faecal coliforms 6/100ml, Desertegney - faecal coliforms 44/100ml, Drumcairn - faecal coliforms 2/100ml, Drumogill(1) - faecal coliforms 9/100ml, Drumogill(2) - coliforms 20/100ml, Fintown - faecal coliforms 6/100ml, Fintragh - faecal coliforms 800/100ml, Glenagad Housing - faecal coliforms 2/100ml, Gleneely - faecal coliforms 4/100ml, Meentinadea - faecal coliforms 6/100ml, Sieve - faecal coliforms 80/100ml, Townawilly - faecal coliforms 250/100ml, Tullintain - faecal coliforms 1/100ml.

**Drogheda Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supply):** Drogheda Corporation/Rosehall - coliforms 2/100mls, Drogheda Corporation/Staleen - faecal coliforms 1/100mls

**1994 (Local Authority Supply):** Drogheda Corporation/Rosehall - coliforms 2/100mls, Drogheda Corporation/Staleen - coliforms 5/100mls

**1995 (Local Authority Supply):** Drogheda Corporation/Staleen - coliforms 4/100mls

**Dublin Corporation Contaminated Drinking Water:**

**1993 (Local Authority Supplies): (4 supplies)**

Ballymore Eustace - faecal coliforms 2/100 mls, Leixlip - coliforms 2/100 mls, Leixlip-Ballymore - faecal coliforms 1/100 mls, Stillorgan - faecal coliforms 32/100 mls.

**1994 (Local authority supplies): (4 supplies)**

Ballymore Eustace - coliforms 200/100 mls, Leixlip - coliforms 13/100 mls, Leixlip-Stillorgan-Ballymore Eustace - faecal coliforms 2/100 mls, Stillorgan - faecal coliforms 12/100 mls.

**1995 (Local authority supplies): (5 supplies)**

Ballyboden - coliforms 1/100 mls, Ballymore Eustace - coliforms 1/100 mls, Leixlip - faecal coliforms 1/100 mls, Leixlip-Stillorgan-Ballymore Eustace - coliforms 12/100 mls, Stillorgan - faecal coliforms 1/100 mls.

**County Dublin Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (9 supplies)**

Ballyboden - faecal coliforms 4/100 mls, Ballyedmonduff - coliforms 5/100 mls, Ballymore Eustace - faecal coliforms 1/100 mls, Brittas - faecal coliforms 15/100 mls, Glencullen - faecal coliforms 3/100 mls, Kilternan - faecal coliforms 17/100 mls, Leixlip - coliforms 3/100 mls, Leixlip-Stillorgan - faecal coliforms 1/100 mls, Roundwood - faecal coliforms 5/100 mls.

**1994 (Local authority supplies): (8 supplies)**

South Dublin County Council: Ballyboden - faecal coliforms 1/100 mls, Ballymore Eustace - faecal coliforms 5/100 mls,

DunLaoghaire-Rathdown County Council: Ballyboden - faecal coliforms 1/100 mls, Glencullen - coliforms 3/100 mls, Kilternan - faecal coliforms 1/100 mls, Roundwood - coliforms 4/100 mls, Stillorgan - faecal coliforms 1/100 mls.

**1995 (Local authority supplies):**

South Dublin Co.Co. (1 supplies contaminated)

Ballymore Eustace - coliforms 1/100mls.

Fingal County Council (2 supplies contaminated)

Leixlip - faecal coliforms 5/100mls, Leixlip-Stillorgan-Ballymore-Eustace - faecal coliforms 1/100mls.

Dun Laoghaire-Rathdown County Council (4 supplies contaminated)

Ballyboden - faecal coliforms 1/100mls; Glencullen - coliforms 7/100mls, Kilternan - coliforms 4/100mls, Roundwood - faecal coliforms 3/100mls.

**Dundalk UDC Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies):** Cavan Hill (River Fane) - coliforms 1/100ml

**1993 (Group Water Schemes):** Dunbin - faecal coliforms 1/100mls

**1994 (Group Water Schemes):** Dunbin - faecal coliforms 18/100mls

**1995 (Local Authority Supplies/Group Water Schemes):** None contaminated

**Dun Laoghaire Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)**

Stillorgan - faecal coliforms 4/100ml

**1994 (Local Authority Supplies): (5 supplies)**

Ballyboden - faecal coliforms 1/100ml, Glencullen - coliforms 3/100ml, Kilternan - faecal coliforms 1/100ml, Roundwood - coliforms 4/100ml, Stillorgan - faecal coliforms 1/100ml

**Galway Corporation:**

**1993 (Local Authority Supplies):** None

**1994 (Local Authority Supplies):** None

**1995 (Local Authority Supplies):** Old Water Works - 2 faecal coliforms/100 mls

**County Galway Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (10 supplies)**

Clifden - coliforms 10/100mls, Dunmore - faecal coliforms 20/100mls, Headford- faecal coliforms 1/100mls, Inishshere - faecal coliforms 12/100mls, Inishmore (Aran Islands) - faecal coliforms 12/100mls, Kilconnell - faecal coliforms 2/100mls, Leenane - faecal coliforms 1/100mls, Letterfrack - faecal coliforms 1/100mls, Roundstone - faecal coliforms 22/100mls, Teeranea-Lettermore - faecal coliforms 2/100mls.

**1993 (Group Water Schemes): (60 supplies)**

Ardrahan - faecal coliforms 4/100mls, Aughrim - faecal coliforms 4/100mls, Aughrisbeg - faecal coliforms 25/100mls, Ballinakill - faecal coliforms 8/100mls, Ballingarry - faecal coliforms 2/100mls, Bealadangan - faecal coliforms 42/100mls, Briarfield No.2 - faecal coliforms 1/100mls, Cahernashilleeny - coliforms 80/100mls, Caltra/Bymacward/Casblakeney - faecal coliforms 240/100mls, Carra - faecal coliforms 33/100mls, Carraghy - faecal coliforms 2/100mls

Drumgriffin - coliforms 8/100mls, Dunally (Peterswell) - faecal coliforms 6/100mls, Emlough - faecal coliforms 2/100mls, Gannocks-Aughrismore - faecal coliforms 2/100mls, Garrafrauns - faecal coliforms 40/100mls, Garryland No 1 (Gort) - faecal coliforms 26/100mls, Garrymore - faecal coliforms 10/100mls, Glebe (Cummer) - faecal coliforms 6/100mls, Gortnaclossa - faecal coliforms 4/100mls, Greyford (Kiltulla) - faecal coliforms 30/100mls, Gurraun North (Tuam) - faecal coliforms 20/100mls, Inishmeain - faecal coliforms 360/100mls, Inishnee - coliforms 1/100mls, Kilchreest -

coliforms 2/100mls, Kilcolgan - faecal coliforms 1/100mls, Kilconly - faecal coliforms 123/100mls, Killalaloonty No - faecal coliforms 1/100mls, Killasolan - faecal coliforms 1600/100mls, Killeen-Poultallon - faecal coliforms 3000/100mls, Killina (Kinvara) - faecal coliforms 2/100mls, Killoran - faecal coliforms 160/100mls, Kiltевна (Dunmore) - coliforms 10/100mls, Knock Central - faecal coliforms 2/100mls, Knockbrack (Athenry) - faecal coliforms 32/100mls, Knockdoe (Claregalway) - faecal coliforms 24/100mls, Lecarrow (Craughwell) - faecal coliforms 1/100mls, Lettercallow (Lettermore) - faecal coliforms 6/100mls, Lettergesh/Mullaghglass - faecal coliforms 480/100mls, Lettermullen (Lough Hibbert) - faecal coliforms 36/100mls, Lowville - faecal coliforms 140/100mls, Maam - faecal coliforms 7/100mls, Masonbrook - faecal coliforms 2/100mls, Milltown - faecal coliforms 1/100mls, Monivea - faecal coliforms 2/100mls, Moy (Kinvara) - faecal coliforms 10/100mls, Mullaghcuttery - faecal coliforms 58/100mls, Rakerin-Annagh - coliforms 1/100mls, Ramore - faecal coliforms 2/100mls, Roveagh (Kilcolgan) - coliforms 2/100mls, Rusheens (Tuam) - faecal coliforms 3/100mls, Shradoo - faecal coliforms 1/100mls, Slievefinn-Auclogeen - faecal coliforms 4/100mls, Streamstown (Clifden) - faecal coliforms 2/100mls, Streamstown No 2 - faecal coliforms 2/100mls, Tiernascragh - faecal coliforms 1/100mls, Tomanybraher - faecal coliforms 60/100mls, Treananearla - faecal coliforms 12/100mls, Tullira-Coxtown - faecal coliforms 1/100mls, Turrabeg - faecal coliforms 44/100mls, Woodfield (Dunmore) - faecal coliforms 4/100mls.

**1994 (Local Authority Supplies): (14 supplies)**

Ballinasloe - faecal coliforms 3/100mls, Carraroe - faecal coliforms 18/100mls, Clifden - faecal coliforms 1/100mls, Derryinver - faecal coliforms 8/100mls, Derryrush - coliforms 0/100mls, Galway City - coliforms 1/100mls, Inishmore (Aran Islands) - faecal coliforms 2000/100mls, Kilconnell - faecal coliforms 120/100mls, Leenane - faecal coliforms 14/100mls, Loughrea - faecal coliforms 1/100mls, Rosmuc - faecal coliforms 10/100mls, Roundstone - faecal coliforms 300/100mls, Spiddal - coliforms 18/100mls, Tully/Tully Cross - faecal coliforms 4/100mls, Williamstown - faecal coliforms 2000/100mls.

**1994 (Group Water Schemes): (78 supplies)**

Ardaun-Dooroy - faecal coliforms 1/100mls, Ardrahan - faecal coliforms 6/100mls, Aughrim - faecal coliforms 360/100mls, Ballinakill - faecal coliforms 5/100mls, Ballinakill/Moyard - faecal coliforms 6/100mls, Ballyaneen - faecal coliforms 14/100mls, Ballyroebackbeg - faecal coliforms 12/100mls, Belmont/Kilconly - faecal coliforms 20/100mls, Brackloon-Guteen - faecal coliforms 32/100mls, Briarfield No.1 - faecal coliforms 1000/100mls, Bunnahevally-Kilcurrivard - faecal coliforms 1/100mls, Cahermorris - coliforms 16/100mls, Caltra-Ballymacward-Castleclakeney - coliforms 16/100mls, Cappagh-Ballyshrul - coliforms 10/100mls, Carra(Bullaun) - faecal coliforms 80/100mls, Carraghy (Claregalway) - faecal coliforms 232/100mls, Cartymore (Athenry) - faecal coliforms 59/100mls, Cashla (Athenry) - coliforms 1/100mls, Castlelambert-Knock - faecal coliforms 25/100mls, Castletaylor (Ardrahan) - coliforms 2/100mls, Claren-Knocklehard - faecal coliforms 38/100mls, Cloghagalla - faecal coliforms 8/100mls, Clonbrock (Pallas) - faecal coliforms 27/100mls, Cloonatleva - faecal coliforms 60/100mls, Cloonluane (Renvyle) - faecal coliforms 36/100mls, Cluide (Cahermorris) - faecal coliforms 2/100mls, Clunarne (Turloughmore) - faecal coliforms 20/100mls, Coraneena - coliforms 6/100mls, Corrandulla - faecal coliforms 35/100mls, Crannagh (Gort) - faecal coliforms 14/100mls, Cuillagh (abbey) - faecal coliforms >100,000/100mls (.), Derrybrien no.1 - faecal coliforms 20/100mls, Derrygimla - faecal coliforms 1/100mls, Doone (Ahascragh) - faecal coliforms 42/100mls, Esker - faecal coliforms 8/100mls, Foreglass-Dolan - faecal coliforms 1/100mls, Gannocks-Aughrismore - faecal coliforms 12/100mls, Glann (Oughterard) - faecal coliforms 2/100mls, Glebe (Cummer) - faecal coliforms 12/100mls, Glengowla no 3 - faecal

coliforms 4/100mls, Glinsk - faecal coliforms 8/100mls, Gortnaclossa - faecal coliforms 4/100mls, Grange (Claregalway) - faecal coliforms 30/100mls, Inishmeain - faecal coliforms 900/100mls, Kilconly - faecal coliforms 80/100mls, Kilcrimble - coliforms 200/100mls, Killalaghton - coliforms 4/100mls, Killasolan - faecal coliforms 24/100mls, Killeen-Brocky - faecal coliforms 10/100mls, Killina (Kinvara) - faecal coliforms 12/100mls, Killiny (Gort) - coliforms 2/100mls, Killoran (Ballinasloe) - faecal coliforms 300/100mls, Kiltulla (Athenry)- faecal coliforms 800/100mls, Knockbrack (Athenry) - faecal coliforms 140/100mls, Kylephrasogue - faecal coliforms 16/100mls, Lettergesh/Mullaghglass - faecal coliforms 211/100mls, Lettermullen (Lough Hibbert) - faecal coliforms 44/100mls, Lisnagrenshy - faecal coliforms 4/100mls, Lowville - faecal coliforms 138/100mls, Maam - faecal coliforms 50/100mls, Mail Road (Oatfield) - faecal coliforms 60/100mls, Menlough (Ballinasloe) - faecal coliforms 24/100mls, Milltown - faecal coliforms 24/100mls, Milltown North-East - faecal coliforms 60/100mls, Moy (Kinvara) - faecal coliforms 68/100mls, Ower (Headford) - faecal coliforms 8/100mls, Pallas (Tynagh) - faecal coliforms 6/100mls, Palmerstown - faecal coliforms 110/100mls, Parkroe (Kinvara) - faecal coliforms 16/100mls, Rakerin-Annagh - faecal coliforms 8/100mls, Rakerin No 2 - coliforms 40/100mls, Rea (Woodford) - faecal coliforms 1/100mls, Rhynn (Killeeneen) - faecal coliforms 82/100mls, Rineen (Gort) - coliforms 4/100mls, Roveagh (Kilcolgan) - faecal coliforms 31/100mls, Rusheens (Tuam) - coliforms 4/100mls, Slieverue (Athenry) - faecal coliforms 192/100mls, Streamstown No 2 - faecal coliforms 20/100mls, Woodfield (Dunmore) - faecal coliforms 30/100mls.

**1995 (Local Authority Supplies): (9 supplies)**

Ballinasloe - faecal coliforms 10/100mls, Brierfield - faecal coliforms >50000/100mls, Cleggan/Claddaghduff - faecal coliforms 2/100mls, Inishere (Aran Islands) - faecal coliforms 4/100mls, Inishmore - faecal coliforms 4/100mls, Mid-Galway Regional - faecal coliforms 52/100mls, Roundstone - faecal coliforms 1/100mls, Tuam - coliforms 30/100mls, Tully/Tully Cross - coliforms 4/100mls.

**1995 (Group Water Schemes): (89 supplies)**

Arbbert - faecal coliforms 1/100mls, Abbeylands - faecal coliforms 8/100mls, Anbaly and District - faecal coliforms 3/100mls, Annaghdown No 1 - faecal coliforms 8/100mls, Ardaun-Dooroy - faecal coliforms 64/100mls, Aughtrim - faecal coliforms 44/100mls, Ballinakill - faecal coliforms 16/100mls, Ballinakill/Moyard - faecal coliforms 14/100mls, Ballyaneen - faecal coliforms 12/100mls, Ballyvoneen-Castlefrench - faecal coliforms 8/100mls, Barnaderg/Tuam - coliforms 6/100mls, Belmont/Kilconly - faecal coliforms 22/100mls, Biggera/Belclare - faecal coliforms 1/100mls, Boyounagh-Ballyedmond- faecal coliforms 5/100mls, Brackloon-Guteen - faecal coliforms 28/100mls, Briarfield No.1 - faecal coliforms 5/100mls, Briarfield No.2 - faecal coliforms 2/100mls, Caherlistrane - coliforms 6/100mls, Cahermorris - coliforms 12/100mls, Carnaun-Castle Ellen - faecal coliforms 14/100mls, Carraghy (Claregalway) - faecal coliforms 40/100mls, Carrarea-Killoran - faecal coliforms 5/100mls, Cashla (Athenry) - coliforms 2/100mls, Castlelambert-Knock - faecal coliforms 200/100mls, Claren-Knocklehard - coliforms 4/100mls, Claretuam - faecal coliforms 4/100mls, Cloghagalla - faecal coliforms 16/100mls, Cloonfush / Tuam - faecal coliforms 2/100mls, Cloonluane (Renvyle) - faecal coliforms 3/100mls, Cluide (Cahermorris) - faecal coliforms 80/100mls, Coole/Gort - faecal coliforms 1/100mls, Corrandulla - faecal coliforms 4/100mls, Craughwell - faecal coliforms 24/100mls, Cummer - faecal coliforms 24/100mls Curry/Corofin - faecal coliforms 10/100mls, Derrybrien no.2 - coliforms 40/100mls, Doone (Ahascragh) - faecal coliforms 4/100mls, Drumgriffin - faecal coliforms 2/100mls, Dunally - faecal coliforms 14/100mls, Eastwell - coliforms 2/100mls, Esker - faecal coliforms >20000/100mls, Eyrecourt-Lawrencetown - faecal coliforms 14/100mls, Feagh East & West - coliforms 3/100mls, Gallagher/Brownsgrrove -

faecal coliforms 4/100mls, Garryland No1 / Gort - faecal coliforms 28/100mls, Garryland No2 / Gort - faecal coliforms 12/100mls, Glan/Oughterard - faecal coliforms 3/100mls, Glebe (Cummer) - faecal coliforms 100/100mls, Glengowla no 3 - faecal coliforms 6/100mls, Glinsk - faecal coliforms 40/100mls, Gortnaclossa - faecal coliforms 28/100mls, Gortnasillagh - faecal coliforms 3/100mls, Grange (Claregalway) - faecal coliforms 100/100mls, Greyford/Kiltulla - faecal coliforms 12000/100mls, Inchaboy - faecal coliforms 8/100mls, Inishmeain - faecal coliforms 12/100mls, Kilbannon - faecal coliforms 160/100mls, Kilcloghans - coliforms 14/100mls, Kilconly - faecal coliforms 3/100mls, Kilcrimple - coliforms 3/100mls, Killasolan - faecal coliforms 32/100mls, Killina (Kinvara) - faecal coliforms 1/100mls, Killiny (Gort) - faecal coliforms 4/100mls, Kiltormer - coliforms 50/100mls, Kiltulla (Athenry)- faecal coliforms 800/100mls, Knockbrack (Athenry) - faecal coliforms 72/100mls, Kylemore Abbey - faecal coliforms 180/100mls, Lecarrow/Craughwell - faecal coliforms 6/100mls, Lissalondon - faecal coliforms 4/100mls, Lowville No 1- faecal coliforms 280/100mls, Maam - faecal coliforms 80/100mls, Mail Road (Oatfield) - faecal coliforms 16/100mls, Masonbrook - faecal coliforms 8/100mls, Moy (Kinvara) - faecal coliforms 1/100mls, Newcastle / Aughrim - faecal coliforms 240/100mls, Oaklands (Headford) - faecal coliforms 5/100mls, Peterswell Village - faecal coliforms 18/100mls, Rakerin No 2 - coliforms 130/100mls, Rakerin-Annagh - faecal coliforms 70/100mls, Ratesh (Kilconly) - faecal coliforms 40/100mls, Rindifin (Gort) - faecal coliforms 2/100mls, Rineen (Gort) - coliforms 3/100mls, Roveagh (Kilcolgan) - faecal coliforms 26/100mls, Shanover (Tynagh) - coliforms 2/100mls, Streamstown (Clifden) faecal coliforms 2/100mls, Toberroe (Glinsk) - faecal coliforms 20/100mls, Turrabeg (Gort) - faecal coliforms 44/100mls, Wallscourt - faecal coliforms 4/100mls, Willow End - faecal coliforms 4/100mls.

**County Kerry Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (44 supplies)**

Annascaul - coliforms 1/100mls, Ardferit South-Fenit - coliforms 24/100mls, Aughacasla - faecal coliforms 3/100mls, Ballinloghig - coliforms 1/100mls, Ballybunion [Galey River] - faecal coliforms 1/100mls, Ballyduff - coliforms 4/100mls, Ballyferriter - coliforms 5/100mls, Barraduff - coliforms 14/100mls, Brandon - faecal coliforms 2/100mls, Brosna - faecal coliforms 24/100mls, Caherciveen - faecal coliforms 2/100mls, Camp - faecal coliforms 2/100mls, Cappagh - faecal coliforms 6/100mls, Caragh Lake - coliforms 19/100mls, Castlegregory - faecal coliforms 5/100mls, Central Regional - coliforms 1/100mls, Cloghane - coliforms 63/100mls, Dawros - coliforms 53/100mls, Dingle - coliforms 2/100mls, Duagh - faecal coliforms 1/100mls, Fahan - faecal coliforms 1/100mls, Fenit - coliforms 2/100mls, Glenbeigh - faecal coliforms 1/100mls, Glenfahan - faecal coliforms 6/100mls, Graigue-Clogher - faecal coliforms 8/100mls, Kilgarvan - coliforms 7/100mls, Kilmalkeadar - coliforms 3/100mls, Killorglin - Faecal coliforms 1/100mls, Lauragh - coliforms 31/100mls, Lissavigeen - coliforms 1/100mls, Lixnaw - coliforms 6/100mls, Lyreacrompane-NE Kerry - coliforms 5/100mls, Mid-Kerry Regional - faecal coliforms 16/100mls, Milltown - faecal coliforms 10/100mls, Minard No 1 - coliforms 9/100mls, Mountain Stage - faecal coliforms 14/100mls, Murreigh - faecal coliforms 2/100mls, Rathmore - coliforms 8/100mls, Reenard Regional - faecal coliforms 2/100mls, Scartaglin - coliforms 13/100mls, Sneem - faecal coliforms 9/100mls, Teeravane - faecal coliforms 7/100mls, Ventry - coliforms 1/100mls, Waterville - coliforms 4/100mls.

**1994 (Local Authority Supplies): (56 supplies)**

Abbeydorney-Kilflynn - coliforms 9/100mls/100mls, Ardfert South-Fenit - coliforms 4/100mls, Ballinavenooragh - faecal coliforms 57 /100mls, Ballinskelligs - faecal coliforms 10 /100mls, Ballybunion [Galey River] - faecal coliforms 1/100mls, Ballyduff - faecal coliforms 4/100mls, Ballyferriter - coliforms 5/100mls, Ballymore - faecal coliforms 37/100mls, Ballywiheen - coliforms 2/100mls, Barraduff - faecal coliforms 11/100mls, Brosna - faecal coliforms 7/100mls, Caherciveen - faecal coliforms 2/100mls, Caherboshina - faecal coliforms 41/100mls, Caherdaniel - coliforms 5/100mls, Camp - faecal coliforms 94 /100mls, Cappagh - faecal coliforms 31/100mls, Caragh Lake - coliforms 15/100mls, Castlecove - faecal coliforms 2/100mls, Castlegregory - faecal coliforms 16/100mls, Central Regional - coliforms 1/100mls, Dawros - coliforms 14/100mls, Dingle - coliforms 14/100mls, Duagh - coliforms 11/100mls, Dunquin - faecal coliforms 7/100mls, Fahan - faecal coliforms 5/100mls, Fenit - faecal coliforms 6/100mls, Feohanagh - faecal coliforms 2/100mls, Glen - faecal coliforms 65 /100mls, Glenbeigb - faecal coliforms 17 /100mls, Glenfahan - faecal coliforms 9/100mls, Gneeveguilla - coliforms 7/100mls, Graigue-Clogher - faecal coliforms 5/100mls, Inch Regional - faecal coliforms 9 /100mls, Kenmare - coliforms 1/100mls, Kilgarvan - coliforms 1/100mls, Kilmalkeadar - coliforms 4/100mls, Killorglin - coliforms 17/100mls, Knockavrogeen - faecal coliforms 2/100mls, Lauragh - coliforms 5/100mls, Liscarney - faecal coliforms 6 /100mls, Lissavigeen - coliforms 1/100mls, Lyreacrompane-NE Kerry - coliforms 6/100mls, Mid-Kerry Regional - faecal coliforms 3/100mls, Milltown - faecal coliforms 15/100mls, Minard No 1 - coliforms 2/100mls, Minard No 2 - faecal coliforms 13/100mls, Mountain Stage - faecal coliforms 3/100mls, Murreigh - faecal coliforms 13/100mls, Portmagee - faecal coliforms 28/100mls, Rathmore - faecal coliforms 1/100mls, Reenard Regional - faecal coliforms 1/100mls, Scartaglin - coliforms 34/100mls, Sneem - faecal coliforms 79/100mls, Teeravane - faecal coliforms 2/100mls, Ventry - faecal coliforms 2/100mls, Waterville - coliforms 1/100mls.

**1995 (Local Authority Supplies): (37 supplies)**

Ardfert North-Ballyheigue - faecal coliforms 2/100mls, Ardfert South -Fenit - coliforms 2/100mls, Ballinskelligs - faecal coliforms 6/100mls, Ballybunion [Galey River] - coliforms 9/100mls, Barraduff - faecal coliforms 12/100mls, Brosna - faecal coliforms 48/100mls, Caherdaniel - faecal coliforms 2/100mls, Caragh Lake - coliforms 1/100mls, Castlegregory - Stradbally - faecal coliforms 13/100mls, Causeway - faecal coliforms 3/100mls, Central Regional - coliforms 6/100mls, Dawros - faecal coliforms 4/100mls, Dingle - faecal coliforms 6/100mls, Dunquin - faecal coliforms 1/100mls, Emlaghpeasta - faecal coliforms 20/100mls, Fahan - coliforms 16/100mls, Fenit - coliforms 91/100mls, Glen - faecal coliforms 25 /100mls, Glenbeigb - faecal coliforms 17 /100mls, Glenfahan - faecal coliforms 2/100mls, Graigue-Clogher - coliforms 1/100mls, Kenmare - coliforms 55/100mls, Killorglin - faecal coliforms 6/100mls, Lauragh - coliforms 7/100mls, Liscarney - faecal coliforms 3/100mls, Lixnaw - coliforms 3/100mls, Lyreacrompane-NE Kerry Reg. - faecal coliforms 1/100mls, Mid-Kerry Regional - coliforms 1/100mls, Milltown - faecal coliforms 3/100mls, Minard No 2 - faecal coliforms 10/100mls, Portmagee - coliforms 16/100mls, Rathmore - faecal coliforms 88/100mls, Reenard Regional - faecal coliforms 4/100mls, Scartaglin - coliforms 1/100mls, Sneem - faecal coliforms 6/100mls, Teeravane - faecal coliforms 9/100mls, Waterville - faecal coliforms 99/100mls.

**County Kildare Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (7 supplies)**

Ballykelly-Monasterevan - faecal coliforms 93/100mls, Ballytore-Moone-Timolin - faecal coliforms 43/100mls, Castlemitchel Housing - faecal coliforms 2/100mls, Johnstownbridge - coliforms 16/100mls, Leixlip Regional - faecal coliforms 1/100mls, Poulaphouca Regional - faecal coliforms 1/100mls, Redbog - coliforms 4/100mls.

**1993 (Group Water Schemes): (3 supplies)**

Gormanstown - coliforms 4/100mls, Hempstown - faecal coliforms >500/100mls, Wolfestown - coliforms 2/100mls

**1994 (Local Authority Supplies): (7 supplies)**

Ballytore-Moone-Timolin - faecal coliforms 26/100mls, Clonuff (Broadford) - coliforms 100/100mls, Johnstownbridge - coliforms 8/100mls, Kilmeade (Athy) - faecal coliforms 1/100mls, Naas - coliforms 33/100mls, Poulaphouca Regional - faecal coliforms 2/100mls, Redbog - coliforms 4/100mls.

**1994 (Group Water Schemes): (2 supplies)**

Ballindoolin - coliforms 7/100mls, Ballyroe - coliforms 2/100mls.

**1995 (Local Authority Supplies): (12 supplies)**

Ballytore-Moone-Timolin - faecal coliforms 31/100mls, Belview - faecal coliforms 12/100mls, Bullock Park (Naas) - coliforms 14/100mls, Castledermott(Plunketstown) - coliforms 1/100mls, Castlemitchel(Churchtown) - coliforms 1/100mls, Clogherenkoe - coliforms 6/100mls, Johnstownbridge - coliforms 5/100mls, Kilberry (Athy) - faecal coliforms 2/100mls, Leixlip Regional - faecal coliforms 1/100mls, Monasterevan - faecal coliforms 1/100mls, Naas Urban - faecal coliforms 1/100mls, Poulaphouca Regional - faecal coliforms 1/100mls.

**1995 (Group Water Schemes): (4 supplies)**

Ballindoolin - coliforms >1000/100mls, Gormanstown - coliforms 20/100mls, Hempstown - coliforms 10/100mls, Narraghmore-Lipstown - faecal coliforms 7/100mls.

**County Kilkenny Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (10 supplies)**

Bennettsbridge Regional - coliforms 16/100mls, Catlecomer - faecal coliforms 4/100mls, Clogh-Castlecomer - faecal coliforms 4/100mls, Glenmore - coliforms 22/100mls, Inistioge - coliforms 8/100mls, Kilkenny/Radestown - coliforms 3/100mls, Kilkenny/Troyswod - coliforms 270/100mls, Piltown-Fiddown - coliforms 2/100mls, Thomastown - coliforms 280/100mls, Urlingford-Johnstown - coliforms 4/100mls

**1994 (Local Authority Supplies): (9 supplies)**

Ballyragget - faecal coliforms 12/100mls, Bennettsbridge Regional - coliforms 16/100mls, Callan - coliforms 4/100mls, Catlecomer - faecal coliforms 300/100mls, Clogh-Castlecomer - faecal coliforms 3/100mls, Glenmore - faecal coliforms 2/100mls, Graiguenamanagh - coliforms 6/100mls, Kilkenny/Radestown - coliforms 530/100mls, Kilkenny/Troyswod - faecal coliforms 124/100mls.

**1995 (Local Authority Supplies): (10 supplies)**

Ballyragget - faecal coliforms 4/100mls, Bennettsbridge Regional - coliforms 2/100mls, Catlecomer - faecal coliforms 8/100mls, Clogh-Castlecomer - faecal coliforms 11/100mls, Glenmore - faecal coliforms 18/100mls, Graiguenamanagh - coliforms 2/100mls, Inistioge - coliforms 6/100mls, Kilkenny/Radestown - coliforms 6/100mls, Kilkenny/Troyswod - faecal coliforms 500/100mls, Piltown-Fiddown - faecal coliforms 13/100mls.

**County Laois Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (4 supplies)**

Durrow - faecal coliforms 4/100mls, Mountrath - faecal coliforms 280/100mls, Portarlinton - faecal coliforms 27/100mls, Shanbeg (Rosenallis) - faecal coliforms 1/100mls.

**1994 (Local Authority Supplies): (8 supplies)**

Mountmellick - coliforms 4/100mls, Mountrath - coliforms 3/100mls, Oakley Park - coliforms 54/100mls, Portarlinton - coliforms 4/100mls, Portlaoise - faecal coliforms 3/100mls, Rosenallis - coliforms 2/100mls, Stradbally - coliforms 4/100mls, Vicarstown - coliforms 1/100mls.

**1995 (Local Authority Supplies): (12 supplies)**

Emo - coliforms 8/100mls, Mountmellick - faecal coliforms 1/100mls, Mountrath - coliforms 1/100mls, Portarlinton - faecal coliforms 1/100mls, Shanbeg/Rosenallis - faecal coliforms 1/100mls

**1995 (Group Water Schemes): (7 supplies)**

Ballacolla - faecal coliforms 2/100mls, Ballinabranagh - coliforms 12/100mls, Cullohill - faecal coliforms 1/100mls, Donaghmore - faecal coliforms 1/100mls, Errill - coliforms 1/100mls, The Heath - faecal coliforms 4/100mls, Mount Salem - faecal coliforms 5/100mls.

**County Leitrim Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (7 supplies)**

Carrigallen - faecal coliforms 6/100mls, Dromahaire - faecal coliforms 4/100mls, Fivemilebourne - faecal coliforms 21/100mls, Kinlough-Tullaghan - faecal coliforms 46/100mls, Manorhamilton - faecal coliforms 36/100mls, Rossinver - faecal coliforms 6/100mls, Drumshambo - coliforms 1/100mls.

**1993 (Group Water Schemes): (4 supplies)**

Ardvolley-Killavoggy - faecal coliforms 3/100mls, Aughacashel - faecal coliforms 24/100mls, Errif - faecal coliforms 8/100mls, Leckanarainey - faecal coliforms 250/100mls.

**1994 (Local authority supplies): (8 supplies)**

Ballinamore coliforms 23/100mls, Drumkeerin coliforms 8/100mls, Drumshambo coliforms 3/100mls, Fivemilebourne - faecal coliforms 40/100mls, Kinlough-Tullaghan coliforms 2/100mls, Manorhamilton - faecal coliforms 100/100mls, Rooskey - coliforms 2/100mls, Rossinver - coliforms 20/100mls

**1994 (Group Water Schemes): (3 supplies)**

Ardmoneen - faecal coliforms 92/100mls, Creevelea - faecal coliforms 2/100mls, Drumlegga - faecal coliforms 16/100mls.

**1995 (Local authority supplies): (4 supplies)**

Carrigallen coliforms 1/100mls, Rossinver - coliforms 11/100mls, S.Leitrim Regional - Dromod - coliforms 20/100mls, S.Leitrim Regional - Rooskey - coliforms 3/100mls

**1994 (Group Water Schemes): (10 supply results missing)**

**Limerick Corp. Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies):**

Limerick City (Corporation) - coliforms 3/100ml.

**1994 (Local Authority Supplies):**

Limerick City (Corporation) - coliforms 33/100ml.

**1995 (Local Authority Supplies):**

Limerick City (Corporation) - faecal coliforms 1/100ml.

**Co. Limerick Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (16 supplies)**

Athlacca - faecal coliforms 21/100mls, Ballyhahill - coliforms 1/100mls, Bilboa-Faleen - faecal coliforms 10/100mls, Caherdavin - coliforms 1/100mls, Carrigkerry - coliforms 2/100mls, Castleconnell - faecal coliforms 66/100mls, Doon - coliforms 1/100mls, Fedamore - coliforms 3/100mls, Kilmallock - coliforms 5/100mls, Kilteely - coliforms 6/100mls, Mountcollins - faecal coliforms 1/100mls, Newcastlewest - faecal coliforms 2/100mls, Rathkeale - faecal coliforms 100/100mls, Shannon Estuary - coliforms 1/100mls, South West Regional - coliforms 2/100mls, Tournafulla - faecal coliforms 45/100mls.

**1993 (Group Water Schemes): (27 supplies)**

Ballinlyna - faecal coliforms 1/100mls, Ballyorgan - coliforms 1/100mls, Ballysteen West - faecal coliforms 10/100mls, Ballysteen East - faecal coliforms 25/100mls, Breska - faecal coliforms 14/100mls, Caherass - faecal coliforms 23/100mls, Cappagh - faecal coliforms 8/100mls, Castle-Erkin - faecal coliforms 2/100mls, Craggs - coliforms 4/100mls, Creeves - coliforms 5/100mls, Croagh - coliforms 3/100mls, Dromin - coliforms 100/100mls, Dromtrasna - coliforms 3/100mls, Feenagh - faecal coliforms 3/100mls, Glenastar - coliforms 66/100mls, Gortnagluggin - faecal coliforms 1000/100mls, Granagh - faecal coliforms 7/100mls, Griston - coliforms 28/100mls, Kilcornan - faecal coliforms 3/100mls, Kilfinny - faecal coliforms 3/100mls, Killeedy-Ballagh - faecal coliforms 35/100mls, Monerla - faecal coliforms 100/100mls, Newbridge - faecal coliforms 1/100mls, Rockhill - coliforms 70/100mls, Sugar Hill - coliforms 1/100mls, Templeathea East - coliforms 1/100mls, Templeglantine - faecal coliforms 300/100mls.

**1994 (Local Authority Supplies): (11 supplies)**

Adare - faecal coliforms 3/100mls, Askeaton - coliforms 1/100mls, Althea - faecal coliforms 5/100mls, Athlacca - faecal coliforms 13/100mls, Bruff - coliforms 26/100mls, Carrigkerry - coliforms 150/100mls, Castlemahon - coliforms 1/100mls, Croom - coliforms 19/100mls, Glin - coliforms 1/100mls, Newcastlewest - coliforms 4/100mls, Tournafulla - faecal coliforms 100/100mls.

**1994 (Group Water Schemes): (33 supplies)**

Ashroe - coliforms 2/100mls, Ballintona - faecal coliforms 14/100mls, Ballinvreena - coliforms 5/100mls, Ballyduff - faecal coliforms 5/100mls, Ballynacourty - faecal coliforms 100/100mls, Ballyorgan - coliforms 1/100mls, Ballyshonickbane - faecal coliforms 100/100mls, Ballysteen - faecal coliforms 26/100mls, Caherass - faecal coliforms 11/100mls, Cahernorry - faecal coliforms 5/100mls, Cappagh - coliforms 1/100mls, Carnane - faecal coliforms 2/100mls, Craggs - coliforms 1/100mls, Creeves - faecal coliforms 13/100mls, Cullane North - coliforms 1/100mls, Falleen - faecal coliforms 4/100mls, Farrandonnelly - coliforms 1/100mls, Feenagh - faecal coliforms 3/100mls, Glenstal - faecal coliforms 7/100mls, Gortnagluggin - coliforms 100/100mls, Greenane - coliforms 11/100mls, Inch St Lawrence - faecal coliforms 2/100mls, Kilcornan - faecal coliforms 4/100mls, Kilfinny - coliforms 3/100mls, Kilglass - faecal coliforms 100/100mls, Killeedy-Ballagh - faecal coliforms 8/100mls, Killeen - coliforms 55/100mls, Knockea - coliforms 8/100mls, Meenoline - faecal coliforms 100/100mls, Newbridge - faecal coliforms 2/100mls, Newtown - faecal coliforms 69/100mls, Newtown/Caherline - coliforms 5/100mls, Templeglantine - coliforms 9/100mls.

**1995 (Local Authority Supplies): (17 supplies)**

Abbeyfeale - coliforms 2/100mls, Adare - coliforms 8/100mls, Athlacca - faecal coliforms 5/100mls, Ballyhahill - coliforms 1/100mls, Banoge - faecal coliforms 30/100mls, Bruff - coliforms 2/100mls, Caherconlish - coliforms 2/100mls, Cappamore - coliforms 2/100mls, Castlemahon - coliforms 3/100mls, Glenastar - coliforms 4/100mls,

Glin - coliforms 2/100mls, Herbertstown - coliforms 1/100mls, Kilmallock - faecal coliforms 2/100mls, Mountcollins - faecal coliforms 2/100mls, Oola - faecal coliforms 41/100mls, Rathkeale - coliforms 1/100mls, Shanagolden - coliforms 1/100mls.

**1995 (Group Water Schemes): (30 supplies)**

Ashroe - coliforms 2/100mls, Ballinstona South - faecal coliforms 39/100mls, Ballinvreena - coliforms 1/100mls, Ballybricken - coliforms 1/100mls, Ballyduff - faecal coliforms 1/100mls, Ballynacourty - faecal coliforms 100/100mls, Ballyshonickbane - faecal coliforms 17/100mls, Ballysteen - coliforms 9/100mls, Breska - faecal coliforms 60/100mls, Caherass - faecal coliforms 13/100mls, Cahernorry - faecal coliforms 11/100mls, Cappagh No 2 - faecal coliforms 3/100mls, Carnane - faecal coliforms 3/100mls, Clovers - coliforms 1/100mls, Craggs - faecal coliforms 1/100mls, Creeves - faecal coliforms 11/100mls, Cullane North - faecal coliforms 11/100mls, Dromtrasna - coliforms 1/100mls, Feenagh - faecal coliforms 1/100mls, Glenstal - faecal coliforms 100/100mls, Gortnagluggin - coliforms 2/100mls, Granagh - faecal coliforms 2/100mls, Kilcornan - faecal coliforms 1/100mls, Kilfinny - coliforms 2/100mls, Kilglass - faecal coliforms 86/100mls, Lissowen - faecal coliforms 2/100mls, Meenoline - faecal coliforms 8/100mls, Newbridge - faecal coliforms 4/100mls, Newtown - faecal coliforms 4/100mls, Templeglantine - faecal coliforms 3/100mls.

**Listowel Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies):** (1 supply) Listowel Urban - faecal coliforms 10/100mls

**1994 (Local Authority Supplies):** (1 supply) Listowel Urban - faecal coliforms 30/100mls

**1995 (Local Authority Supplies):** (1 supply) Listowel Urban - faecal coliforms 2/100mls

**Co. Longford Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (3 supplies)**

Ballinallee-Edgeworthstown - coliforms 23/100mls, Ballymahon Regional - coliforms 1/100mls, Kenagh Regional - faecal coliforms 10/100mls.

**1994 (Local Authority Supplies): (2 supplies)**

Longford Central Regional - coliforms 1/100mls, Kenagh Regional - faecal coliforms 3/100mls

**1995 (Local Authority Supplies): (3 supplies)**

Ballymahon Regional - faecal coliforms 1/100mls, Longford Central Regional - coliforms 12/100mls, Newtowncashel - faecal coliforms 4/100mls

**Co. Louth Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (8 supplies)**

Ardee - faecal coliforms 1/100mls, Brownstown - faecal coliforms 2/100mls, Carlingford - faecal coliforms 10/100mls, Greenore - faecal coliforms 3/100mls, Killineer - coliforms 192/100mls, Omeath - faecal coliforms 57/100mls, Rathmore - coliforms 2/100mls, Sheelagh-Courtbane - faecal coliforms 7/100mls.

**1993 (Group Water Schemes): (7 supplies)**

Dunbin - faecal coliforms 43/100mls, Grangebellow - faecal coliforms 22/100mls, Kilkerley - faecal coliforms 13/100mls, Killanny-Reaghstown - faecal coliforms 5/100mls, Ravensdale - coliforms 3/100mls, Sheepgrange - faecal coliforms 40/100mls, Tullyallen - faecal coliforms 1/100mls.

**1994 (Local Authority Supplies): (5 supplies)**

Ardee - faecal coliforms 10/100mls, Clogherhead-Termonfeckin - coliforms 1/100mls, Greenmount - coliforms 37/100mls, Killineer - coliforms 34/100mls, Tallanstown - faecal coliforms 2/100mls.

**1994 (Group Water Schemes): (7 supplies)**

Drybridge - coliforms 2/100mls, Dunbin - faecal coliforms 20/100mls, Grangebellow - faecal coliforms 4/100mls, Jenkinstown - coliforms 5/100mls, Kilkerley - coliforms 2/100mls, Sheepgrange - coliforms 9/100mls, Tullyallen - faecal coliforms 1/100mls.

**1995 (Local Authority Supplies): (8 supplies)**

Brownstown - coliforms 5/100mls, Carlingford - coliforms 1/100mls, Clogherhead-Termonfeckin - coliforms 3/100mls, Greenmount - coliforms 1/100mls, Greenmore - faecal coliforms 35/100mls, Killiner - coliforms 57/100mls, Omeath - faecal coliforms 1/100mls, Sheelagh-Courtbane - coliforms 5/100mls.

**1995 (Group Water Schemes): (10 supplies)**

Ardaghy - faecal coliforms 16/100mls, Ballymakenny - coliforms 1/100mls, Drybridge - coliforms 22/100mls, Dunbin - faecal coliforms 9/100mls, Grangebellow - faecal coliforms 1/100mls, Jenkinstown - coliforms 3/100mls, Kilkerley - faecal coliforms 3/100mls, Ravensdale - faecal coliforms 1/100mls, Sheepgrange - coliforms 79/100mls, Tullyallen - faecal coliforms 7/100mls.

**Co. Meath Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (9 supplies)**

Drumconrath - coliforms 6/100mls, Dunboyne/Clonee - faecal coliforms 164/100mls, East Meath Regional - faecal coliforms 460/100mls, Kells/Oldcastle - coliforms 15/100mls, Kilmessan - faecal coliforms 180/100mls, Longwood - coliforms 6/100mls, Navan-Mid Meath Regional - coliforms 2/100mls, Nobber - faecal coliforms 27/100mls, Slane - faecal coliforms 1/100mls.

**1993 (Group Water Schemes): (2 supplies)**

Kilmainham Wood - faecal coliforms 42/100mls, Lobinstown - coliforms 2/100mls.

**1994 (Local Authority Supplies): (10 supplies)**

Ashbourne - coliforms 3/100mls, Athboy - faecal coliforms 15/100mls, Castletown - faecal coliforms 100/100mls, Duleek - faecal coliforms 3/100mls, Dunboyne/Clonee - coliforms 14/100mls, Enfield - coliforms 14/100mls, Killmainhamwood - faecal coliforms 12/100mls, Navan Mid Regional - faecal coliforms 8/100mls, Summerhill - coliforms 19/100mls.

**1994 (Group Water Schemes): (1 supplies)**

Kiltale - faecal coliforms 20/100mls.

**1995 (Local Authority Supplies): (10 supplies)**

Ballivor - faecal coliforms 1000/100mls, Castletown - faecal coliforms 17/100mls, Clonard - faecal - coliforms not available, Drumconrath - faecal coliforms 10/100mls, Duleek - faecal coliforms 1/100mls, Dunboyne/Clonee - faecal coliforms 154/100mls, Killmainhamwood - faecal coliforms 2/100mls, Kilmessan - faecal coliforms 2/100mls, Navan Mid Regional - coliforms 19/100mls, Trim - coliforms 1/100mls.

**1995 (Group Water Schemes): (6 supplies)**

Drumgill - coliforms 1/100mls, Drumgill-Meath Hill - faecal coliforms 1000/100mls, Dunsany - faecal coliforms 2/100mls, Irishtown - coliforms 1/100mls, Kiltale - faecal coliforms 1/100mls, Lobinstown - coliforms 5/100mls.

**Co. Monaghan Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (4 supplies)**

Glaslough - coliforms 1/100mls, Killyneill - coliforms 1/100mls, Newbliss - coliforms 2/100mls, Smithborough - coliforms 4/100mls.

**1993 (Group Water Schemes): (12 supplies)**

Aughnamullen - faecal coliforms 8/100mls, Baraghy - faecal coliforms 17/100mls, Corduff - faecal coliforms 23/100mls, Donaghmoynne - faecal coliforms 60/100mls, Doohamlet - coliforms 27/100mls, Drumully - faecal coliforms 3/100mls, Glaslough-Tyholland - faecal coliforms 4/100mls, Killanny - faecal coliforms 11/100mls, Pullis - faecal coliforms 5/100mls, Scotshouse - faecal coliforms 27/100mls, Stranooden - faecal coliforms 35/100mls, Tydavnet - coliforms 1/100mls.

**1994 (Local Authority Supplies): (5 supplies)**

Clonibret - coliforms 5/100mls, Emyvale - faecal coliforms 5/100mls, Glaslough - coliforms 1/100mls, Newbliss - faecal coliforms 3/100mls, Rockcorry - faecal coliforms 2/100mls,

**1994 (Group Water Schemes): (11 supplies)**

Aughnamullen - faecal coliforms 11/100mls, Aughnashlavey - faecal coliforms 2/100mls, Baraghy - faecal coliforms 8/100mls, Corduff - coliforms 5/100mls, Donaghmoynne - faecal coliforms 1/100mls, Doohamlet - coliforms 2/100mls, Drumgoole - faecal coliforms 1/100mls, Glaslough-Tyholland - faecal coliforms 47/100mls, Pullis - faecal coliforms 47/100mls, Scotshouse - faecal coliforms 9/100mls, Stranooden - faecal coliforms 46/100mls.

**1995 (Local Authority Supplies): (9 supplies)**

Clonibret - coliforms 1/100mls, Drum - coliforms 10/100mls, Emyvale - coliforms 1/100mls, Glaslough - faecal coliforms 1/100mls, Inniskeen - coliforms 11/100mls, Newbliss - faecal coliforms 3/100mls, Rockcorry - faecal coliforms 2/100mls, Scotstown-Ballinode - faecal coliforms 1/100mls, Smithborough - coliforms 3/100mls.

**1995 (Group Water Schemes): (13 supplies)**

Baraghy - faecal coliforms 16/100mls, Churchill-Oram - coliforms 1/100mls, Corduff - coliforms 14/100mls, Donaghmoynne - faecal coliforms 18/100mls, Doohamlet - coliforms 1/100mls, Drumgoole - faecal coliforms 8/100mls, Drumully - faecal coliforms 1/100mls, Glaslough-Tyholland - faecal coliforms 3/100mls, Killanny - faecal coliforms 14/100mls, Pullis - faecal coliforms 4/100mls, Stranooden - coliforms 36/100mls, Truagh - coliforms 4/100mls, Tydavnet - coliforms 6/100mls.

**Monaghan UDC Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)** Monaghan - coliforms 50/100mls

**1994 (Local Authority Supplies): (1 supply)** Monaghan - faecal coliforms 1/100mls

**1995 (Local Authority Supplies): (1 supply)** Monaghan - faecal coliforms 18/100mls

**County Mayo Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (12 supplies)**

Balla - faecal coliforms 16/100mls, Ballina Regional coliforms 2/100mls, Ballindine - faecal coliforms 2/100mls, Ballycastle coliforms 6/100mls, Bangor Erris - faecal coliforms 1600/100mls, Claremorris - faecal coliforms 18/100mls, Cong - faecal coliforms 2/100mls, Kiltimagh - faecal coliforms 4000/100mls, Knock - faecal coliforms 32/100mls, Newport - faecal coliforms 1/100mls, Shrule - faecal coliforms 4/100mls, Swinford - faecal coliforms 8/100mls.

**1993 (Group Water Schemes): (5 supplies)**

Barnacarroll - faecal coliforms 4/100mls, Bofield - faecal coliforms 28/100mls, Clare Island - faecal coliforms 36/100mls, Hollymount - faecal coliforms 60/100mls, Kilcolman/Drumneen - coliforms 2/100mls

**1994 (Local authority supplies): (10 supplies)**

Balla - faecal coliforms 20/100mls, Ballindine - faecal coliforms 24/100mls, Ballyhaunis - faecal coliforms 6/100 mls, Bangor Erris - faecal coliforms 24/100mls, Kilmaine - coliforms 14/100 mls, Kiltimagh - faecal coliforms 14/100mls, Knock - faecal coliforms 12/100mls, Lough Mask Reg. - faecal coliforms 4/100mls, Mulranny - faecal coliforms 10/100mls, Shrule - faecal coliforms 2/100 mls.

**1994 (Group Water Schemes):(45 supplies)**

Ballinchalla - faecal coliforms 24/100mls, Ballycroy coliforms 8/100mls, Ballyvary - faecal coliforms 18/100mls, Banogues - faecal coliforms 4/100mls, Barnacarroll coliforms 4/100mls, Bekan - faecal coliforms 1/100mls, Belmont/Kilconly - faecal coliforms 14/100mls, Bofeenaun - faecal coliforms 1/100mls, Bohola - faecal coliforms 70/100mls, Carrowkeel/Hollymount - faecal coliforms 12/100mls, Carrowkeel,Murrisk - faecal coliforms 15/100mls, Cashel,Charlestown coliforms 4/100mls, Clare Island - faecal coliforms 26/100mls, Cloonmore/Cloonlavish - faecal coliforms 120/100mls, Coogue/Knock - faecal coliforms 24/100mls, Cregduff - faecal coliforms 14/100mls, Creggbaun - faecal coliforms 6/100mls, Crossboyne - faecal coliforms 36/100mls, Currykirwan coliforms 10/100mls, Derryhick,Parke coliforms 9/100mls, Dooyork West - faecal coliforms 2/100mls, Drumindoo,Westport - faecal coliforms 4/100mls, Furnace - faecal coliforms 24/100mls, Glenamoy - faecal coliforms 4/100mls, Glencorrib - faecal coliforms 2/100mls, Glenhest/Newport - faecal coliforms 12/100mls, Gortnaclossa - faecal coliforms 3/100mls, Greenwood - faecal coliforms 4/100mls, Holywell - faecal coliforms 6/100mls, Johnstown - faecal coliforms 2/100mls, Keelogue - faecal coliforms 6/100mls, Keenaghmore - faecal coliforms 10/100mls, Kilcony/Shrulle - faecal coliforms 12/100mls, Killeen - coliforms 4/100mls, Lahardane - faecal coliforms 110/100mls, Lislackagh - faecal coliforms 32/100mls, Lisatava/Hollymount coliforms 6/100mls, Manulla - faecal coliforms 12/100mls, Mayo Abbey - faecal coliforms 2/100mls, Meelick - faecal coliforms 22/100mls, Milford - faecal coliforms 4/100mls, Mocharra/Schrulle - faecal coliforms 24/100mls, Monard coliforms 6/100mls, Robeen,Hollymount - faecal coliforms 2/100mls, Rooskey,Charlestown - faecal coliforms 14/100mls.

**1995 (Local authority supplies): (12 supplies)**

Balla - faecal coliforms 40/100mls, Ballina Reginal Water Supply - faecal coliforms 2/100mls, Ballindine - faecal coliforms 40/100mls, Ballycastle - faecal coliforms 5/100mls, Ballyhaunis - faecal coliforms 14/100 mls, Bangor Erris - faecal coliforms 40/100mls, Belmullet Regional - coliforms 2/100mls, Claremorris - faecal coliforms 20/100mls, Kilmaine - coliforms 4/100 mls, Kiltimagh - coliforms 10/100mls, Swinford - faecal coliforms 20/100mls, Westport - faecal coliforms 4/100 mls.

**1995 (Group Water Schemes): (8 supplies - 102 supplies were not tested or reported.)**

Belcarra - faecal coliforms 2/100mls, Bofeenaun - faecal coliforms 1/100mls, Clare Island - faecal coliforms 60/100mls, Cloghan's Hill - faecal coliforms 8/100mls, Coogue - faecal coliforms 2/100mls, Lahardane - faecal coliforms 9/100mls, Rathkell - faecal coliforms 2/100mls, Tooreen/Aghamore - faecal coliforms 14/100mls.

**Co. Offaly Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (7 supplies)**

Birr - faecal coliforms >100/100mls, Clara - coliforms 2/100mls, Cloonbulloge - faecal coliforms 40/100mls, Kinnitty - coliforms 4/100mls, Mountbolus - faecal coliforms 50/100mls, Rahan - coliforms 2/100mls, Shinrone - faecal coliforms 12/100mls.

**1993 (Group Water Schemes): (14 supplies)**

Aghancon - faecal coliforms 8/100mls, Ballinagar - coliforms 2/100mls, Ballyboy - faecal coliforms 40/100mls, Ballyfore - coliforms 4/100mls, Boher - coliforms 2/100mls, Bracknagh - faecal coliforms 80/100mls, Brosna - faecal coliforms 2/100mls, Clareen - faecal coliforms 2/100mls, Cloneygowan - faecal coliforms 20/100mls, Durrow - faecal coliforms 24/100mls, Killeigh - faecal coliforms 50/100mls, Leamore/Leabeg - faecal coliforms >100/100mls, Mountlucas - faecal coliforms 2/100mls, Tober - faecal coliforms 12/100mls.

**1994 (Local Authority Supplies): (9 supplies)**

Cloonbulloge - coliforms 31/100mls, Coolderry - coliforms 28/100mls, Daingean - coliforms 2/100mls, Kinnitty - faecal coliforms 2/100mls, Rahan - coliforms 8/100mls, Shannonbridge - faecal coliforms 2/100mls, Shinrone - faecal coliforms 100/100mls., Tullamore - faecal coliforms 2/100mls, Walsh Island - faecal coliforms 18/100mls.

**1994 (Group Water Schemes): (13 supplies)**

Aghancon - faecal coliforms 20/100mls, Ballinagar - coliforms 10/100mls, Ballyboy - faecal coliforms >100/100mls, Ballyfore - coliforms 1/100mls, Bracknagh - faecal coliforms >100/100mls, Brosna - faecal coliforms 13/100mls, Clareen - faecal coliforms 2/100mls, Durrow - faecal coliforms 100/100mls, Killeigh - faecal coliforms 1/100mls, Leamore - faecal coliforms >28/100mls, Meelaghans - coliforms 5/100mls, Mountlucas - faecal coliforms 11/100mls, Tober - faecal coliforms 13/100mls.

**1995 (Local Authority Supplies): (6 supplies)**

Banagher - faecal coliforms >100/100mls, Clara - coliforms >100/100mls, Geashill - coliforms 7/100mls, Rahan - faecal coliforms >100/100mls, Rhode - coliforms 2/100mls, Shinrone - faecal coliforms >100/100mls.

**1995 (Group Water Schemes): (12 supplies)**

Aghancon - faecal coliforms 80/100mls, Ballinagar - coliforms 36/100mls, Ballyboy - faecal coliforms 12/100mls, Ballyfore - faecal coliforms 6/100mls, Boher - faecal coliforms 2/100mls, Brosna - faecal coliforms 100/100mls, Clareen - coliforms 2/100mls, Killeigh - faecal coliforms 20/100mls, Leamore - faecal coliforms 20/100mls, Meelaghans - faecal coliforms 10/100mls, Mountlucas - faecal coliforms 6/100mls, Tober - faecal coliforms 13/100mls.

**Co. Roscommon Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (5 supplies)**

Arigna-Mount Allen - faecal coliforms 6/100mls, Ballinlough-Loughglynn - faecal coliforms 13/100mls, Knockcroghery Regional - faecal coliforms 126/100mls, Roscommon Town - faecal coliforms 1/100mls, South Roscommon Regional - coliforms 2/100mls.

**1993 (Group Water Schemes): (18 supplies)**

Ardkeenagh - faecal coliforms 1/100mls, Aughrim-Creeve - faecal coliforms 1/100mls, Ballymacfrane-Donamon - faecal coliforms 1/100mls, Brosna (Ballaghadereen) - faecal coliforms 10/100mls, Carane-Ballintubber - faecal coliforms 4/100mls, Carane-Castle Plunkett - coliforms 2/100mls, Carane-Whitehall - coliforms 2/100mls, Carnalassan-Caggle - faecal coliforms 3/100mls, Carroward-Four Mile House - faecal coliforms 10/100mls, Castlestrange - faecal coliforms 2/100mls, Clooncullane - coliforms 10/100mls, Cloonygrassan - faecal coliforms 1/100mls, Corrastona - coliforms

8/100mls, Emlagh-Donamon - coliforms 2/100mls, Grange-Four Mile House - faecal coliforms 9/100mls, Ogulla - faecal coliforms 1/100mls, Peake-Mantua - faecal coliforms 220/100mls, Rathcarran-Ballintubber - faecal coliforms 8/100mls.

**1994 (Local Authority Supplies): (4 supplies)**

Ballinlough-Loughglynn - faecal coliforms 20/100mls, Keadue - faecal coliforms 6/100mls, North Roscommon Regional - faecal coliforms 200/100mls, Upper Rover/Arigna - faecal coliforms 1/100mls.

**1994 (Group Water Schemes): (26 supplies)**

Ardkeenagh - faecal coliforms 32/100mls, Aughrim-Creeve - faecal coliforms 400/100mls, Ballymacfrane-Donamon - faecal coliforms 840/100mls, Brosna (Ballaghadereen) - coliforms 2/100mls, Camlin-Ballinamewn - faecal coliforms 24/100mls, Carane-Ballintubber - faecal coliforms 60/100mls, Carane-Whitehall - coliforms 400/100mls, Carnalassan-Caggle - faecal coliforms 180/100mls, Carroward-Four Mile House - faecal coliforms 300/100mls, Castlestrange - faecal coliforms 420/100mls, Clooncullane - coliforms 6/100mls, Clooneygrassan - faecal coliforms 360/100mls, Croghan - faecal coliforms 80/100mls, Derrane-Cooltigue - faecal coliforms 160/100mls, Derryphatten-Cloonybeirne - coliforms 2/100mls, Emlaghmore - faecal coliforms 64/100mls, Gortaganny - coliforms 30/100mls, Grange-Four Mile House - faecal coliforms 600/100mls, Ogulla - faecal coliforms 60/100mls, Oldtown - faecal coliforms 2/100mls, Peake-Mantua - faecal coliforms 22/100mls, Rahara - faecal coliforms 80/100mls, Rathcarran-Ballintubber - faecal coliforms 600/100mls, Rathcroghan - faecal coliforms 36/100mls, Rathmore-Four Mile House - faecal coliforms 50/100mls, Shadlough - faecal coliforms 54/100mls.

**1995 (Local Authority Supplies): (9 supplies)**

Arigna-Mount Allen - faecal coliforms 6/100mls, Ballinagare - faecal coliforms 60/100mls, Ballyfarnon - faecal coliforms 12/100mls, Ballyleague - faecal coliforms >300/100mls, Boyle Town - faecal coliforms 1/100mls, Castlerea Regional - coliforms 12/100mls, Knockcrogherty Regional - faecal coliforms 44/100mls, NE Roscommon Regional - faecal coliforms 10/100mls, Roscommon Town - faecal coliforms 16/100mls.

**1995 (Group Water Schemes): (19 supplies)**

Ardkeenagh - faecal coliforms 12/100mls, Ballymacurley - faecal coliforms 210/100mls, Carane-Ballintubber - faecal coliforms 8/100mls, Carane-Whitehall - faecal coliforms 88/100mls, Carroward-Four Mile House - faecal coliforms 10/100mls, Clooneygrassan - faecal coliforms 10/100mls, Clooneyquinn - faecal coliforms 32/100mls, Clootuskert - faecal coliforms 13/100mls, Corbally-Boherroe - faecal coliforms 4/100mls, Corrastoona - faecal coliforms 10/100mls, Derrincartha - faecal coliforms 14/100mls, Derryphatten-Cloonybeirne - faecal coliforms 2/100mls, Grange-Four Mile House - faecal coliforms 50/100mls, Ogulla - faecal coliforms 6/100mls, Oldtown - faecal coliforms 8/100mls, Peake-Mantua - faecal coliforms 170/100mls, Rathcarran-Ballintubber - faecal coliforms 90/100mls, Rathcroghan - faecal coliforms 10/100mls, Shadlough - faecal coliforms 3/100mls, Tarmonbarry - faecal coliforms 60/100mls.

**Sligo Town Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)** Kilsellagh - faecal coliforms 0/100mls

**1994 (Local Authority Supplies): (1 supply)** Kilsellagh - coliforms >15/100mls

**1995 (Local Authority Supplies): (1 supply)** Kilsellagh - coliforms 0/100mls

**Co. Sligo Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (6 supplies)**

Ballysodare - faecal coliforms 1/100mls, Enniscrone - coliforms 1/100mls, Grange - faecal coliforms 1/100mls, Gurteen - faecal coliforms 1/100mls, Mullaghmore - faecal coliforms 101/100mls, Strandhill - faecal coliforms 1/100mls.

**1993 (Group Water Schemes): (12 supplies)**

Ballintogher - faecal coliforms >100/100mls, Ballintrillick - faecal coliforms 60/100mls, Ballygawley - faecal coliforms 36/100mls, Benbulbin - faecal coliforms 101/100mls, Calry No.1 - faecal coliforms 23/100mls, Calry No.2 - faecal coliforms 72/100mls, Culfadda - faecal coliforms 10/100mls, Doomore - faecal coliforms 2/100mls, Drum East - faecal coliforms 50/100mls, Geevagh/Highwood - faecal coliforms 1/100mls, Lough na Leibe - faecal coliforms 9/100mls, Ransboro - faecal coliforms 6/100mls.

**1994 (Local Authority Supplies): (6 supplies)**

Ballymote Regional - faecal coliforms 5/100mls, Ballysodare - coliforms 2/100mls, Bunnanadden - coliforms 6/100mls, Coolaney- coliforms 1/100mls, Strandhill - coliforms 1/100mls, Tubbercurry - coliforms 1/100mls.

**1994 (Group Water Schemes): (8 supplies)**

Ballinafad - faecal coliforms 18/100mls, Ballintogher - faecal coliforms >100/100mls, Ballintrillick - faecal coliforms 11/100mls, Ballygawley - faecal coliforms 3/100mls, Calry - faecal coliforms 9/100mls, Culfadda - faecal coliforms 4/100mls, Drum East - faecal coliforms 9/100mls, Geevagh/Highwood - faecal coliforms 5/100mls.

**1995 (Local Authority Supplies): (5 supplies)**

Aclare - coliforms 25/100mls, Ballysodare - coliforms 7/100mls, Coolaney- coliforms 2/100mls, Mullaghmore- faecal coliforms 3/100mls, Sligo (Pearse Road) - coliforms 3/100mls,

**1995 (Group Water Schemes): (9 supplies)**

Ballinafad - faecal coliforms 54/100mls, Ballintrillick - faecal coliforms 8/100mls, Ballygawley - faecal coliforms 51/100mls, Benbulbin - faecal coliforms >100/100mls, Carrickbannagher - faecal coliforms 32/100mls, Culfadda - faecal coliforms 65/100mls, Drum East - faecal coliforms >100/100mls, Geevagh/Highwood - faecal coliforms 5/100mls, Geevagh - faecal coliforms 1/100mls.

**Tipperary-NR Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (6 supplies)**

Borrisoleigh - faecal coliforms 22/100mls, Bouladuff - faecal coliforms 1/100mls, Nenagh - faecal coliforms 10/100mls, Newtown - coliforms 1/100mls, Portroe-Garrykennedy - coliforms 9/100mls, Templemore - faecal coliforms 200/100mls.

**1994 (Local Authority Supplies): (1 supplies)**

Whitefield - coliforms 2/100mls

**1995 (Local Authority Supplies): (4 supplies)**

Ballinaclough-Kilkeary - coliforms 33/100mls, Cloughjordan - coliforms 1/100mls, Glenbeha - coliforms 1/100mls, Whitefield - faecal coliforms 2/100mls.

**Tipperary-SR Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (10 supplies)**

Ballinvir - faecal coliforms 1/100mls, Burncourt Regional - faecal coliforms 1/100mls, Clogheen - faecal coliforms 1/100mls, Commons - coliforms 2/100mls, Glengar - coliforms 30/100mls, Gortnapisha Regional - faecal coliforms 150/100mls, Graigue - faecal coliforms 3000/100mls, Hollyford - faecal coliforms 14/100mls, Kilcash - faecal coliforms 1/100mls, Tipperary UDC - faecal coliforms 9/100mls.

**1993 (Group Water Schemes): (1 supplies)**

Inchirourke - faecal coliforms 4/100mls.

**1994 (Local Authority Supplies): (11 supplies)**

Ardfinnan Regional - faecal coliforms 160/100mls, Ballincurry - coliforms 1/100mls, Ballinvir - coliforms 1/100mls, Cahir Reservoir - faecal coliforms 6/100mls, Clogheen - coliforms 20/100mls, Cloran Regional - faecal coliforms 14/100mls, Galtee Regional - coliforms 1/100mls, Glengar - coliforms 2/100mls, Gortnapisha Regional - faecal coliforms 106/100mls, Kilcash - faecal coliforms 3/100mls, Killurney - faecal coliforms 40/100mls.

**1994 (Group Water Schemes): (1 supplies)**

Inchirourke - faecal coliforms 4/100mls.

**1995 (Local Authority Supplies): (11 supplies)**

Ahenny - faecal coliforms 14/100mls, Ballincurry - coliforms 1/100mls, Ballinvir - faecal coliforms 28/100mls, Cloran Regional - faecal coliforms 8/100mls, Galtee Regional - faecal coliforms 4/100mls, Glengar - faecal coliforms 1/100mls, Gortnapisha Regional - faecal coliforms 35/100mls, Graigue - faecal coliforms 66/100mls, Kilcash - faecal coliforms 13/100mls, Killurney - faecal coliforms 31/100mls, Mullenbaun - coliforms 3/100mls.

**1995 (Group Water Schemes): (1 supplies)**

Inchirourke - faecal coliforms 5/100mls.

**Co. Waterford Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (27 supplies)**

Ardmore - coliforms 500/100mls, Annestown - coliforms 2/100mls, Ballyduff-Kilmeadon - faecal coliforms 4/100mls, Ballyknock - coliforms 18/100mls, Ballynoe - coliforms 4/100mls, Cappoquin - coliforms 130/100mls, Castlereagh - coliforms 12/100mls, Clonea(O'Sullivan) - faecal coliforms 4/100mls, Clonea(Power) - coliforms 84/100mls, Crehanagh - coliforms 4/100mls, Dungarvan (Mixed supply) - coliforms 8/100mls, Faha - coliforms 54/100mls, Grallagh - coliforms 68/100mls, Kilgobinet-Inchindrisla - coliforms 2/100mls, Kilmacomma - coliforms 2/100mls, Kilmacthomas - faecal coliforms 86/100mls, Kilnafrehan - coliforms 38/100mls, Lacken - faecal coliforms 2/100mls, Loskeran-Gates - coliforms 8/100mls, Moore's Well - coliforms 8/100mls, Nire - faecal coliforms 20/100mls, Poulmagunoge (Clonmel) - faecal coliforms 10/100mls, Ring-Helvic-Seaview - faecal coliforms 40/100mls, Scrothea - coliforms 2/100mls, Tallow - coliforms 26/100mls, Ticknock - faecal coliforms 2/100mls, Tinnabinna - faecal coliforms 8/100mls.

**1994 (Local Authority Supplies): (16 supplies)**

Ballymoate Upper - coliforms 2/100mls, Ballynoe - coliforms 4/100mls, Ballyshunnock - faecal coliforms 60/100mls, Camphire - coliforms 14/100mls, Clonea(Power) - coliforms 12/100mls, Crehanagh - coliforms 4/100mls, Dungarvan (Ballinamuck) - coliforms 2/100mls, East Waterford Regional - coliforms 6/100mls, Faha - coliforms 336/100mls, Graiguenageeha - coliforms 2/100mls, Graiguerush - faecal coliforms 6/100mls, Kilmacthomas - coliforms 120/100mls, Kilrossanty - coliforms 20/100mls, Loskeran-Gates - coliforms 160/100mls, Ring-Helvic-Seaview - faecal coliforms 140/100mls, Tallow - coliforms 2/100mls.

**1995 (Local Authority Supplies): (15 supplies)**

Annestown - faecal coliforms 100/100mls, Ballyheapy - faecal coliforms 10/100mls, Ballynoe - faecal coliforms 9/100mls, Briska - coliforms 1/100mls, Clonea(Power) - faecal coliforms 1/100mls, Crehanagh - coliforms 2/100mls, Currabaha West - coliforms 1/100mls, Feddans - coliforms 1/100mls, Graiguerush - faecal coliforms 1/100mls, Helvic/Ring/Seaview - coliforms 12/100mls, Joanstown - coliforms 4/100mls, Kilbrien -

coliforms 4/100mls, Moore's Well - coliforms 1/100mls, Poulmagunougue - coliforms 9/100mls, Russelstown - faecal coliforms 10/100mls.

**Waterford Corp. Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)** East Waterford Regional - coliforms 5/100mls

**1994 (Local Authority Supplies): (1 supply)** East Waterford Regional - coliforms 6/100mls

**1994 (Local Authority Supplies): None**

**Co. Westmeath Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (8 supplies)**

Ballynacarrigy - faecal coliforms 32/100mls, Ballinahown - faecal coliforms >100/100mls, Castlepollard (High) - coliforms 4/100mls, Castlepollard (Low) - faecal coliforms 2/100mls, Clonmellon - faecal coliforms 30/100mls, Mullingar Regional High - coliforms 4/100mls, Mullingar Regional Low - coliforms 1/100mls, Tyrellspass - faecal coliforms 80/100mls.

**1993 (Group Water Schemes): (2 supplies)**

Mount Temple - coliforms 2/100mls, Multyfarnham - faecal coliforms 100/100mls.

**1994 (Local Authority Supplies): (11 supplies)**

Athlone - faecal coliforms 100/100mls, Ballynacarrigy - faecal coliforms 15/100mls, Castlepollard (High) - faecal coliforms 23/100mls, Castlepollard (Low) - faecal coliforms 4/100mls, Clonmellon - faecal coliforms 20/100mls, Killucan - faecal coliforms 3/100mls, Moate - faecal coliforms 1/100mls, Mullingar Regional High - faecal coliforms 37/100mls, Mullingar Regional Low - coliforms 3/100mls, Mullingar Town Independent Supply - faecal coliforms 100/100mls, Tyrellspass - faecal coliforms >100/100mls.

**1994 (Group Water Schemes): (2 supplies)**

Mount Temple - coliforms >100/100mls, Multyfarnham - faecal coliforms 44/100mls.

**1995 (Local Authority Supplies): (12 supplies)**

Athlone - faecal coliforms 3/100mls, Ballinahown - faecal coliforms 3/100mls, Ballynacarrigy - coliforms 6/100mls, Castlepollard (High) - faecal coliforms 100/100mls, Castlepollard (Low) - faecal coliforms 7/100mls, Clonmellon - faecal coliforms 100/100mls, Killucan - faecal coliforms 6/100mls, Moate - faecal coliforms 100/100mls, Mullingar Regional High - faecal coliforms 2/100mls, Mullingar Regional Low - faecal coliforms 4/100mls, Mullingar Town Independent Supply - faecal coliforms 1/100mls, Tyrellspass - faecal coliforms >100/100mls.

**1995 (Group Water Schemes): (2 supplies)**

Mount Temple - coliforms 10/100mls, Multyfarnham - faecal coliforms 1/100mls.

**Co. Wexford Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (31 supplies)**

Adamstown Housing Scheme - faecal coliforms 4/100mls, Ballinamona - coliforms 2/100mls, Ballindaggin National School - faecal coliforms 33/100mls, Ballyduff national School - faecal coliforms 2/100mls, Ballygarran No.1 Borehole - coliforms 1/100mls, Ballyhine Borehold - coliforms 33/100mls, Ballyoughter National School - coliforms 1/100mls, Ballyroebuck National School - coliforms 80/100mls, Bunclody Village - coliforms 1/100mls, Bunclody-Gorteen - coliforms 2/100mls, Camolin Borehole - faecal coliforms 1/100mls, Castledockrill Housing Scheme - coliforms 2/100mls, Castledockrill National School - coliforms 2/100mls, Clohamon Borehole - coliforms 19/100mls, Clohogue National School - faecal coliforms 3/100mls, Coolgreaney Borehole - coliforms 2/100mls, Craanford National School - coliforms 196/100mls, Cushinstown

National School - coliforms 4/100mls, Davidstown National School - coliforms 1/100mls, Fardystown - coliforms 1/100mls, Ferns - coliforms 1/100mls, Galbally National School - coliforms 5/100mls, Gorey Regional - coliforms 2/100mls, Kilmyshall Housing Scheme - faecal coliforms 1/100mls, Kilnamanagh National School - coliforms 4/100mls, Knockina Reservoir - faecal coliforms 1/100mls, New Ross - faecal coliforms 2/100mls, Oulart Housing Scheme - coliforms 122/100mls, Raheen National School - coliforms 8/100mls, Taghmon - coliforms 9/100mls, Wexford Town - faecal coliforms 2/100mls.

**1993 (Group Water Schemes): (2 supplies)**

Ballymoney-Tara Hill - faecal coliforms 5/100mls, faecal streptococci 1, Rathnure - coliforms 29/100mls.

**1994 (Local Authority Supplies): (23 supplies)**

Ballindaggin National School - faecal coliforms 1/100mls, Ballyfad National School - coliforms 5/100mls, Ballyhine Borehole - coliforms 11/100mls, Barnadown Production Borehole No 1. - coliforms 4/100mls, Bunclody - coliforms 2/100mls, Castledockrill National School - coliforms 2/100mls, Clonroche Borehole - faecal coliforms 6/100mls, Craanford National School - faecal coliforms 29/100mls, Fardystown - coliforms 2/100mls, Galbally National School - coliforms 1/100mls, Gorey Regional - coliforms 1/100mls, Gusserane Housing Scheme - coliforms 2/100mls, Kilegney National School - faecal coliforms 63/100mls, Kilnamanagh National School - faecal coliforms 1/100mls, Monaseed National School - coliforms 28/100mls, New Ross - faecal coliforms 2/100mls, Oulart Housing Scheme - coliforms 4/100mls, Raheen National School - coliforms 1/100mls, Rathgarogue National School - coliforms 3/100mls, South Wexford Regional - faecal coliforms 80/100mls, Sow Regional - coliforms 32/100mls, Taghmon - coliforms 5/100mls, Wexford Town - faecal coliforms 1/100mls.

**1994 (Group Water Schemes): (5 supplies)**

Adamstown - coliforms 10/100mls, Askamore - coliforms 8/100mls, Ballymoney-Tara Hill - coliforms 8/100mls, Ballywilliam - faecal coliforms 444/100mls, Borrmount-Edermine - coliforms 4/100mls.

**1995 (Local Authority Supplies): (19 supplies)**

Ballindaggin National School - coliforms 145/100mls, Ballyellis National School - faecal coliforms 2/100mls, Ballythomas - coliforms 7/100mls, Bunclody - coliforms 4/100mls, Castledockrell Housing Scheme - faecal coliforms 1/100mls, Castledockrill National School - coliforms 14/100mls, Clohamon Boreholes - faecal coliforms 1/100mls, Coolgreaney Borehole - coliforms 1/100mls, Craanford National School - coliforms 67/100mls, Enniscorthy - coliforms 4/100mls, Fardystown - faecal coliforms 1/100mls, Glynn Borehole - coliforms 1/100mls, Gorey Regional - coliforms 2/100mls, Monageer Housing Scheme - coliforms 1/100mls, New Ross - coliforms 4/100mls, South Wexford Regional West - faecal coliforms 4/100mls, Sow Regional - coliforms 1/100mls, Taghmon - faecal coliforms 29/100mls, Wexford Town - coliforms 1/100mls.

**1995 (Group Water Schemes): (3 supplies)**

Askamore - faecal coliforms 36/100mls, Ballymoney-Tara Hill - faecal coliforms 4/100mls, Rathnure - coliforms 2/100mls.

**Co. Wiclow Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (20 supplies)**

Arklow UDC - faecal coliforms 1/100mls, Ballyknockan - faecal coliforms 25/100mls, Baltinglass - faecal coliforms 50/100mls, Blessington - faecal coliforms 90/100mls, Bray Direct - coliforms 3/100mls, Bray Reservoir - coliforms 1/100mls, Donard - faecal coliforms 1/100mls, Dunlavin - faecal coliforms 1/100mls, Enniskerry - coliforms 160/100mls, Glenealy - faecal coliforms 4/100mls, Greystones - faecal coliforms

1/100mls, Hollywood - faecal coliforms 2/100mls, Kirikee Old - faecal coliforms 1/100mls, Knockanarrigan - faecal coliforms 90/100mls, Roundwood - faecal coliforms 3/100mls, Stratford - faecal coliforms 3/100mls, Wicklow Regional - faecal coliforms 3/100mls, Wicklow Regional/Ashford - coliforms 5/100mls, Wicklow Regional/Rathnew - coliforms 5/100mls, Windgates-Templecarrig - faecal coliforms 8/100mls.

**1994 (Local Authority Supplies): (22 supplies)**

Arklow UDC - faecal coliforms 140/100mls, Ashford-Cullenmore - coliforms 25/100mls, Aughrim-Annacurra- coliforms 5/100mls, Avoca-Ballinaclash - coliforms 2/100mls, Barnarrig - coliforms 2/100mls, Enniskerry/Millfield/Kilgarron - coliforms 50/100mls, Glenealy - coliforms 2/100mls, Grangecon - coliforms 17/100mls, Greystones - coliforms 6/100mls, Hollywood/Dunlavin - coliforms 3/100mls, Knockanarrigan - faecal coliforms 90/100mls, Laragh/Annamoe- faecal coliforms 1/100mls, Newcastle-Kilcoole-Newtown-faecal coliforms 9/100mls, Rathdangan- faecal coliforms 25/100mls, Roundwood - faecal coliforms 5/100mls, Stratford - faecal coliforms 4/100mls, Thomastown- coliforms 250/100mls, Tinahely-Carnew - coliforms 3/100mls, Valleymount- coliforms 2/100mls, Wicklow - faecal coliforms 8/100mls, Wicklow Rathnew - faecal coliforms 8/100mls, Windgates-Templecarrig - faecal coliforms 17/100mls.

**1995 (Local Authority Supplies): (25 supplies)**

Arklow UDC - coliforms 6/100mls, Avoca-Ballinaclash - faecal coliforms 5/100mls, Baltinglas - coliforms 8/100mls, Bray (Direct) - faecal coliforms 3/100mls, Bray (Reservoir) - faecal coliforms 2/100mls, Donard - coliforms 2/100mls, Dunlavin-Grangebeg - faecal coliforms 17/100mls, Grangecon - coliforms 3/100mls, Greystones - coliforms 3/100mls, Hollywood/Dunlavin - faecal coliforms 5/100mls, Kiltegan - coliforms 2/100mls, Knockananna - coliforms 1/100mls, Knockanarrigan - coliforms 2/100mls, Laragh/Annamoe - faecal coliforms 13/100mls, Kilcoole-Newtown - coliforms 1/100mls, Newcastle-Kilmacanough - coliforms 1/100mls, Rathdangan - coliforms 160/100mls, Rathdrum - faecal coliforms 2/100mls, Roundwood - faecal coliforms 3/100mls, Stratford - faecal coliforms 92/100mls, Tinahely - coliforms 5/100mls, Tinahely-Carnew - faecal coliforms 2/100mls, Wicklow - coliforms 25/100mls, Wicklow Rathnew - coliforms 13/100mls, Windgates-Templecarrig - coliforms 5/100mls.

**Wicklow Town Contaminated Drinking Water Supplies:**

**1993 (Local Authority Supplies): (1 supply)** Wicklow - coliforms 3/100mls

**1994 (Local Authority Supplies): (1 supply)** Wicklow - coliforms 3/100mls

**1995 (Local Authority Supplies): (1 supply)** Wicklow - coliforms 25/100mls